

General					
Specification Section 15104					
Requirements					
Valve Tag Number					
Quantity					
Size					
inches					
mm					
Type of Service					
Type of Installation (1)					
Ends (2)					
Stems (3)					
Manual Actuator					
Type of manual actuator (4)					
Actuator Accessories					
Extension stems					
Floor boxes					
Cast iron operating stands					
Fabricated steel operating stands					

Notes:

(1) Abbreviations for installation types are as follows:

- B4 Buried, depth of 4 feet [1.2 m] or less
- B20 Buried, depth greater than 4 feet [1.2 m] but 20 feet [6.1 m] or less
- Bxx Buried, depth greater than 20 feet [6.1 m], actual depth of xx feet
- SV20 Submerged or vaulted, depth 20 feet [6.1 m] or less
- SVxx Submerged or vaulted, depth greater than 20 feet [6.1 m], actual depth of xx feet
- IP In plant

(2) Abbreviations for types of ends:

- F Flanged
- MJ Mechanical joint
- P Push-on joint

(3) Abbreviations for types of stems:

- NRS Non-rising stem
- OS&Y Outside screw-and-yoke

(4) Abbreviations for types of manual actuators:

- WN Wrench nut
- HW Handwheel

C					
B					
A					
	DESCRIPTION	DRW	CKD	APP	DATE
REVISIONS					
DRAWN BY: B & V					
CHECKED BY: S.D.A.					
APPROVED:					

**SCHEDULE 15104-S01
RESILIENT-SEATED
GATE VALVES
SCHEDULE**

SCALE: NONE

CITY OF DETROIT
WATER AND SEWERAGE
DEPARTMENT
ENGINEERING
DIVISION

SHEET 1 OF 1

DWG No. 15104-S01