

**BULLETIN NO. 3**

**GREAT LAKES WATER AUTHORITY**

**CONTRACT NO WW-538 (G)**

**Miscellaneous Concrete Crack Repairs and Restoration and Re-Pavement  
of Plant Access Roads at  
Water Works Park II Water Treatment Plant**

**March 30, 2016**

This Bulletin No. 3 is hereby made part of the Contract Documents for the above named project and shall be taken into consideration by any and all bidders submitting bids on this project. All bidders must acknowledge receipt of this Bulletin No. 3 in Section 00300-1, Article 2, The Bidder's Representations, Paragraph 2.1 of the Bid Form.

**CONTRACT DOCUMENTS**

**ITEM 1: Contract drawing D-15-03-002 Please add the following scope of work:**

HMA Pavement Reconstruction for a 10,200 sq. ft parking lot with 21 standard (9 ft x 18 ft) parking spaces and 1 ADA barrier free:

Remove existing 3.5 inches (assumed thickness - to be field verified) HMA. Curb and gutter to remain. Compact existing base course. Adjust existing one catch basin ring elevation as needed. Provide a new 3.5 inches two lift HMA mix #4. See Contract drawing no. D-15-03-109 for parking lot-HMA pavement only. Finish elevations of paving to be field verified and match existing perimeter gutter elevations. Provide pavement marking to 22 parking spaces (21 regular and 1 ADA barrier free) with a 4 inches wide yellow and blue waterborne paint. For location of existing parking, see drawing no. D-15-03-002 (coordinate B-1, 2) and D-15-03-100 (coordinate B-1) on north (Plant North) of Drive "H1".

**ITEM 2: Contract Drawing No. D-15-03-012 please add the following Notes:**

1. Provide pavement marking to 93 parking spaces (89 regular, 4 ADA barriers free).
2. Provide 4 inches wide yellow and blue waterborne paint for the parking spaces marking.

**ITEM 3: Second Site Tour at the Water Works Park II Water Treatment Plant Added**

A second site tour will be held on Friday, April 1, 2016 at Water Work Park II Water Treatment Plant at 10100 East Jefferson Ave., Detroit, Michigan 48214 at 10:00 a.m., Eastern Standard Time. The tour will limited to 30-45 minutes. Participants need to meet at the Water Quality Building. For information on the site tour, call Jorge Nicolas at 313-926-8100. Bidders who attend the site tour are instructed that they must bring their own hard helmets and wear them during the site tour.

**Royal Restoration and Waterproofing email on 03/23/2016**

Question 1: Per Detail 3, Joint Sealant Repair Detail on Sheet D-15-03-306, it notes to reinstall joint sealants to a depth of 2". The manufacturer of any joint sealant material will only warranty a joint depth of a maximum of 1/2".

***Response: Delete "Remove existing joint sealant to a depth of 2" and replace it with "Remove existing joint sealant to a depth of 1/2" on new backer rods".***

**Mark1 Restoration email on 03/25/2016**

Question 1: We would like to return to the Building at Water Works Park II Treatment Plant to re-inspect some of the field conditions and photograph some items. Can we schedule a site visit within the next few days? We did sign the waiver to photograph the buildings at the bid walk

***Response: See Item No. 3 on Page No. 1 of this bulletin.***



---

Daniel Edwards  
Construction and Contract Services  
Procurement Manager