


PERMIT NO. MI0022802


STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENT, GREAT LAKES,
AND ENERGY

**AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Federal Water Pollution Control Act, 33 U.S.C., Section 1251 *et seq.*, as amended; Part 31, Water Resources Protection, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (NREPA); Part 41, Sewerage Systems, of the NREPA; and Michigan Executive Order 2011-1,

City of Detroit Water and Sewerage Department

735 Randolph
Detroit, MI 48226

and

Great Lakes Water Authority

735 Randolph
Detroit, MI 48226

are authorized to discharge from the **Great Lakes Water Authority Water Resource Recovery Facility** located at

9300 W. Jefferson
Detroit, MI 48209

designated as **GLWA WRRF**

to the receiving water named the Detroit River and the Rouge River, and from combined sewer overflow facilities to the receiving waters named the Detroit River, the Rouge River, and Conner Creek in accordance with effluent limitations, monitoring requirements, and other conditions set forth in this permit.

This permit is based on a complete application submitted on March 29, 2017 and amended through May 25, 2017.

This permit takes effect on July 1, 2019. The provisions of this permit are severable. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term in accordance with applicable laws and rules. On its effective date, this permit shall supersede National Pollutant Discharge Elimination System (NPDES) Permit No. MI0022802 (expiring October 1, 2017).

This permit and the authorization to discharge shall expire at midnight on **October 1, 2022**. In order to receive authorization to discharge beyond the date of expiration, the permittees shall submit an application that contains such information, forms, and fees as are required by the Michigan Department of Environment, Great Lakes, and Energy (Department) by **April 4, 2022**.

Issued: June 28, 2019

Original signed by Christine Alexander
Christine Alexander, Manager
Permits Section
Water Resources Division

PERMIT FEE REQUIREMENTS

In accordance with Section 324.3120 of the NREPA, the permittees shall make payment of an annual permit fee to the Department for each October 1 the permit is in effect regardless of occurrence of discharge. The permittees shall submit the fee in response to the Department's annual notice. The fee shall be postmarked by January 15 for notices mailed by December 1. The fee is due no later than 45 days after receiving the notice for notices mailed after December 1.

Annual Permit Fee Classification: Municipal Major, 500 MGD or greater (IP)

In accordance with Section 324.3132 of the NREPA, the permittees shall make payment of an annual biosolids land application fee to the Department if the permittees land applies biosolids. In response to the Department's annual notice, the permittees shall submit the fee, which shall be postmarked no later than January 31 of each year.

CONTACT INFORMATION

Unless specified otherwise, all contact with the Department required by this permit shall be made to the Southeast Michigan District Office of the Water Resources Division. The Southeast Michigan District Office is located at 27700 Donald Court, Warren, MI, 48092-2793, Telephone: 586-753-3700, Fax: 586-751-4690.

CONTESTED CASE INFORMATION

Any person who is aggrieved by this permit may file a sworn petition with the Michigan Administrative Hearing System within the Michigan Department of Licensing and Regulatory Affairs, c/o the Michigan Department of Environment, Great Lakes, and Energy, setting forth the conditions of the permit which are being challenged and specifying the grounds for the challenge. The Department of Licensing and Regulatory Affairs may reject any petition filed more than 60 days after issuance as being untimely.

PART I

Section A. Limitations and Monitoring Requirements

1. Effluent Limitations, Monitoring Point 049F

During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittees are authorized to discharge treated municipal wastewater from Monitoring Point 049F through Outfall 049 (DRO). Outfall 049 (DRO) discharges to the Detroit River. Such discharge shall be limited and monitored by the permittees as specified below.

Until the initiation of operation of the Rouge River Outfall (RRO) Disinfection Project, this discharge shall consist of secondary treated municipal wastewater and additional primary treated municipal wastewater up to the hydraulic capacity of Outfall 049 (DRO). After initiation of operation of the RRO Disinfection Project, this discharge shall consist of secondary treated municipal wastewater typically, but primary treated municipal wastewater and additional secondary treated municipal wastewater up to the hydraulic capacity of Outfall 049 (DRO) during wet weather events. During such wet weather events, the permittees are approved to discharge primary treated municipal wastewater from 049A thorough Outfall 049 (DRO).

Whenever Outfall 049 (DRO) is out of service for repairs, the permittees may discharge through Outfall 050 (RRO). All effluent authorized for discharge from Outfall 049F, and the monitoring, limitations and other requirements specified below shall apply to the discharge through Outfall 050 (RRO) unless otherwise specified. At least 10 days in advance of scheduled maintenance and within 24-hours after initiation of diversion due to emergency conditions, the permittees shall notify the Department of the reason for the diversion and the expected duration of the diversion.

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>				<u>Maximum Limits for Quality or Concentration</u>				<u>Monitoring Frequency</u>	<u>Sample Type</u>
	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>		
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Fecal Coliform Bacteria	---	---	---	---	200	400	---	cts/100 ml	Daily	Grab
Total Residual Chlorine	---	---	---	---	---	---	0.11	mg/l	Daily	Grab
Oil & Grease	---	---	---	---	---	15	---	mg/l	Daily	Grab
Total Polychlorinated Biphenyls (PCBs)										
Aroclor 1016	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1221	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1232	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1242	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1248	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1254	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1260	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
					Maximum PCB Aroclor					
See I.A.1.g.	---	---	---	---	<0.1	---	---	µg/l	Monthly	See I.A.1.g.
Acute Toxicity	---	---	---	---	---	---	(report)	TU _A	Quarterly	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5)										
	---	---	(report)	lbs/day	---	---	(report)	mg/l	Daily	24-Hr Composite
Ammonia Nitrogen (as N)		---	(report)	lbs/day	(report)	---	(report)	mg/l	Daily	24-Hr Composite
Available Cyanide	---	---	(report)	lbs/day	---	---	(report)	µg/l	Monthly	Grab

Perfluorooctane sulfonate (PFOS)	(report)	---	(report)	lbs/day	(report)	---	(report)	ng/l	Quarterly	Grab
Perfluorooctanoic acid (PFOA)	(report)	---	(report)	lbs/day	(report)	---	(report)	ng/l	Quarterly	Grab
Total Copper	---	---	(report)	lbs/day	---	---	(report)	µg/l	Quarterly	24-Hr Composite
					Minimum	Maximum				
					<u>Daily</u>	<u>Daily</u>				
pH	---	---	---	---	6.0	---	9.0	S.U.	Daily	Grab
Dissolved Oxygen	---	---	---	---	(report)	---	---	mg/l	Daily	Grab

The following design flow was used in determining the above limitations, but is not to be considered a limitation or actual capacity: a combined 930 MGD of secondary treated effluent.

- a. **Narrative Standard**
The receiving water shall contain no turbidity, color, oil films, floating solids, foams, settleable solids, or deposits as a result of this discharge in unnatural quantities which are or may become injurious to any designated use.
- b. **Sampling Locations**
The sampling locations for the pollutants indicated in Part I.A.1. of this permit shall be representative of the effluent and consistent with the locations approved by the Department. The Department may approve alternate sampling locations that are demonstrated by the permittees to be representative of the effluent.
- c. **Quarterly Monitoring**
Quarterly samples shall be taken during the months of January, April, July, and October. If the facility does not discharge during these months, the permittees shall sample the next discharge occurring during the period in question. If the facility does not discharge during the period in question, a sample is not required for that period. For any month in which a sample is not taken, the permittees shall enter "*G" on the Discharge Monitoring Report (DMR).
- d. **Total Residual Chlorine (TRC)**
Compliance with the TRC limit shall be determined on the basis of one or more grab samples. If more than one (1) sample per day is taken, the additional samples shall be collected in near equal intervals over approximately eight (8) hours. The samples shall be analyzed immediately upon collection and the average reported as the daily concentration. Samples shall be analyzed in accordance with Part II.B.2. of this permit.
- e. **Monitoring Frequency Reduction for Perfluorooctane Sulfonate (PFOS) and/or Perfluorooctanoic Acid (PFOA)**
After the submittal of 24 months of data, the permittee may request, in writing, Department approval of a reduction in monitoring frequency for PFOS and/or PFOA. This request shall contain an explanation as to why the reduced monitoring is appropriate. Upon receipt of written approval and consistent with such approval, the permittee may reduce the monitoring frequency indicated in Part I.A.1. of this permit. The monitoring frequency for PFOS and/or PFOA, shall not be reduced to less than annually. The Department may revoke the approval for reduced monitoring at any time upon notification to the permittee.
- f. **Analytical Methods and Quantification Levels for Available Cyanide and Total Copper**
The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Available Cyanide shall be in accordance with EPA Method OIA-1677. The quantification level for Available Cyanide and Total Copper shall be 2.0 µg/l and 1.0 µg/l respectively unless a higher level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination. Upon approval from the

Department, the permittees may use alternate analytical methods (for parameters with methods specified in Title 40 of the Code of Federal Regulations (CFR), Part 136, the alternate methods are restricted to those listed in 40 CFR, Part 136).

- g. Limits Below the Quantification Level – Total Polychlorinated Biphenyls (PCBs)
The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Total PCBs shall be in accordance with EPA Method 608.3. Upon approval from the Department, the permittees may use alternate analytical methods (for parameters with methods specified in 40 CFR, Part 136, the alternate methods are restricted to those listed in 40 CFR, Part 136). The quantification level shall be 0.1 ug/l unless a higher level is appropriate because of sample matrix interference. Justification for a higher quantification level shall be submitted to the Department within 30 days of such determination.

The water quality-based effluent limitation for Total PCBs is 2.6×10^{-5} ug/l (2.0×10^{-4} lbs/day) maximum monthly average. This is less than the quantification level. Control requirements are therefore established consistent with R 323.1213. **The discharge of any individual aroclor at or above the quantification level of 0.1 ug/l is a specific violation of this permit.** If concentrations of all aroclors representing a monitoring period are less than their quantification levels, the permittees will be considered to be in compliance with the permit for the monitoring period that the analyses represent, provided that the permittees are also in full compliance with the Pollutant Minimization Program for Total PCBs set forth in Part I.A.10 of this permit. For the purpose of reporting on the Daily tab of the DMR, individual aroclor results less than the quantification level shall be reported as "<0.1." For the purpose of reporting on the Summary tab of the DMR, the value reported under "Maximum PCB Aroclor" shall be the highest aroclor concentration observed during the monitoring period. This permit condition does not authorize the discharge of PCBs at levels that are injurious to the designated uses of the waters of the state or that constitute a threat to the public health or welfare.

- h. Acute Toxicity Requirements
Test species shall include *Ceriodaphnia dubia*. Testing and reporting procedures shall follow procedures contained in EPA-821-R-02-012, "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (Fifth Edition). When the effluent ammonia nitrogen (as N) concentration is greater than 5 mg/l, the pH of the toxicity test shall be maintained at the pH of the effluent at the time of sample collection. The acute toxic unit (TU_A) value for **each species tested** shall be reported on the DMR. For **each species not tested**, the permittees shall enter **"*W"** on the DMR. Completed toxicity test reports for each test conducted shall be retained by the permittees in accordance with the requirements of Part II.B.5. of this permit and shall be available for review by the Department upon request. Toxicity test data acceptability is contingent upon the validation of the test method by the testing laboratory. Such validation shall be submitted to the Department upon request.

The Department will review the toxicity data submitted by the permittees to determine if the acute toxicity requirements of R 323.1219 are being satisfied.

1) If the data indicate persistent exceedance of the acute toxicity requirements of R 323.1219, upon written notification by the Department, the following conditions apply. Within 90 days of the above notification, the permittees shall implement a Toxicity Reduction Evaluation (TRE). The objective of the TRE shall be to reduce the toxicity of the final effluent from Monitoring Point 049F to $<3.0 TU_A$ within three (3) years of notification. The following documents are available as guidance to reduce toxicity to acceptable levels: Phase I, EPA/600/6-91/003; Phase II, EPA/600/R-92/080; Phase III, EPA/600/R-92/081; and Publicly Owned Treatment Works, EPA/833B-99/002. The tests shall be conducted and reported as specified above. Upon approval from the Department, the acute toxicity tests may be performed using the more sensitive species identified in the acute toxicity database. If a more sensitive species cannot be identified, the acute toxicity tests shall be performed with both species. Annual progress reports shall be submitted to the Department within 30 days of the completion of the last test of each annual cycle.

2) This permit may be modified in accordance with applicable laws and rules to include additional whole effluent toxicity control requirements as necessary.

2. Effluent Limitations, Monitoring Point 049A

During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittees are approved to discharge treated municipal wastewater and treated storm water runoff from Monitoring Point 049A through Outfall 049 (DRO). Outfall 049 (DRO) discharges to the Detroit River. Such discharge shall be limited and monitored by the GLWA as specified below.

Monitoring Point 049A is a primary treated effluent conduit. There shall be no discharge from Monitoring Point 049A directly to the Detroit River through Outfall 049 (DRO) unless the discharge from Monitoring Point 049B exceeds a peak hourly flow of 930 MGD (which includes recycle) or in accordance with an approved GLWA Wet Weather Operational Plan (see Part I.A.11.). Discharges from Monitoring Point 049A shall be limited and monitored by the permittees as specified below.

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>			<u>Maximum Limits for Quality or Concentration</u>			<u>Monitoring Frequency</u>	<u>Sample Type</u>		
	<u>Monthly</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>Daily</u>	<u>Units</u>				
Flow	(report)	(report)	MGD	---	---	---	Daily	Report Total Daily Flow		
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	---	---	---	40	(report)	mg/l	Daily	24-Hr Composite		
Total Suspended Solids	---	---	---	70	(report)	mg/l	Daily	24-Hr Composite		
Total Phosphorus (as P)	---	---	---	1.5	(report)	mg/l	Daily	24-Hr Composite		
Ammonia Nitrogen (as N)	---	---	---	(report)	(report)	mg/l	Daily	24-Hr Composite		
Total Mercury										
– Corrected	(report)	(report)	lbs/day	(report)	(report)	ng/l	2x Monthly	Grab		
– Uncorrected	---	---	---	---	(report)	ng/l	2x Monthly	Grab		
– Field Duplicate	---	---	---	---	(report)	ng/l	2x Monthly	Grab		
– Field Corrected	---	---	---	---	(report)	ng/l	2x Monthly	Grab		
– Laboratory Method Blank	---	---	---	---	(report)	ng/l	2x Monthly	Grab		
	<u>12-Month Rolling Average</u>			<u>12-Month Rolling Average</u>						
Total Mercury	0.19	---	---	lbs/day	25	---	---	ng/l	Monthly	Calculation

- a. **Sampling Locations**
The sampling locations for the pollutants in Part 1.A.2. of this permit shall be representative of the effluent and consistent with the locations approved by the Department. Samples for CBOD₅, Total Suspended Solids, Ammonia Nitrogen, Total Mercury, and Total Phosphorus shall be taken prior to mixing with other waste streams. The Department may approve alternate sampling locations that are demonstrated by the permittees to be representative of the effluent
- b. **Sampling of Short-Term Wet Weather Events**
If the first calendar day of the discharge event through Monitoring Point 049A includes less than three hours of flow but continues into the next calendar day, the sampling can be included as a part of the subsequent event the following day.
- c. **Final Effluent Limitation for Total Mercury**
The final limit for total mercury is the Discharge Specific Level Currently Achievable (LCA) based on a multiple discharger variance from the WQBEL of 1.3 ng/l, pursuant to Rule 1103(9) of the Water Quality Standards. Compliance with the LCA shall be determined as a 12-month rolling average, the calculation of which may be done using blank-corrected sample results. The 12-month rolling average shall be determined by adding the present monthly average result to the preceding 11 monthly average results then dividing the sum by 12. For facilities with quarterly monitoring requirements for total mercury, quarterly monitoring shall be equivalent to three (3) months of monitoring in calculating the

12-month rolling average. Facilities that monitor more frequently than monthly for total mercury must determine the monthly average result, which is the sum of the results of all data obtained in a given month divided by the total number of samples taken, in order to calculate the 12-month rolling average. If the 12-month rolling average for any month is less than or equal to the LCA, the GLWA will be considered to be in compliance for total mercury for that month, provided the GLWA is also in full compliance with the Pollutant Minimization Program for Total Mercury, set forth in Part I.A.10. of this permit.

The permittee may choose to demonstrate that an alternate site-specific LCA is appropriate and request a permit modification. Such request and supporting documentation shall be submitted in writing to the Department. Supporting documentation shall include a minimum of 12 samples taken over 12-month period in accordance with EPA Method 1631. Upon approval, this permit may be modified in accordance with applicable laws and rules to incorporate the alternate site-specific LCA as the effluent limitation for Total Mercury.

After a minimum of 12 monthly data points have been collected, the permittees may request a reduction in the monitoring frequency for total mercury. This request shall contain an explanation as to why the reduced monitoring is appropriate and shall be submitted to the Department. Upon receipt of written approval and consistent with such approval, the permittees may reduce the monitoring frequency for total mercury indicated in Part I.A.2. of this permit. The Department may revoke the approval for reduced monitoring at any time upon notification to the permittees.

d. Total Mercury Testing and Additional Reporting Requirements

The analytical protocol for total mercury shall be in accordance with EPA Method 1631, Revision E, "Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Atomic Fluorescence Spectrometry." The quantification level for total mercury shall be 0.5 ng/l, unless a higher level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination.

The use of clean technique sampling procedures is required unless the permittees can demonstrate to the Department that an alternate sampling procedure is representative of the discharge. Guidance for clean technique sampling is contained in EPA Method 1669, Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels (Sampling Guidance), EPA-821-R96-001, July 1996. Information and data documenting the permittee's sampling and analytical protocols and data acceptability shall be submitted to the Department upon request.

In order to demonstrate compliance with EPA Method 1631E and EPA Method 1669, the permittees shall report, on the daily sheet, the analytical results of all field blanks and field duplicates collected in conjunction with each sampling event, as well as laboratory method blanks when used for blank correction. The permittees shall collect at least one (1) field blank and at least one (1) field duplicate per sampling event. If more than ten (10) samples are collected during a sampling event, the permittees shall collect at least one (1) additional field blank AND field duplicate for every ten (10) samples collected. Only field blanks or laboratory method blanks may be used to calculate a concentration lower than the actual sample analytical results (i.e., a blank correction). Only one (1) blank (field OR laboratory method) may be used for blank correction of a given sample result, and only if the blank meets the quality control acceptance criteria. If blank correction is not performed on a given sample analytical result, the permittees shall report under "Total Mercury – Corrected" the same value reported under "Total Mercury – Uncorrected." The field duplicate is for quality control purposes only; its analytical result shall not be averaged with the sample result.

				Minimum Monthly					
CBOD ₅ Minimum % Removal	---	---	---	85	---	---	%	Monthly	Calculation
Total Suspended Solids Minimum % Removal			---	85	---	---	%	Monthly	Calculation

- a. **Sampling Locations**
 Samples for CBOD₅, Total Suspended Solids, Ammonia Nitrogen, Total Phosphorus, Total Mercury and pH shall be taken prior to mixing with other waste streams. Samples for pH shall be collected only during periods of discharge from Monitoring Point 049A through Outfall 049 (DRO).
- b. **Percent Removal Requirements**
 These requirements shall be calculated based on the monthly (30-day) effluent CBOD5 and TSS concentrations and the monthly influent concentrations for approximately the same period.
- c. **Total Phosphorus Six Month Average Limit (April - September)**
 The six month average shall be determined by adding the six monthly average results from April through September and dividing the sum by six. For the purpose of reporting on the Discharge Monitoring Reports, the permittees shall calculate and report the six month average on the October Discharge Monitoring Report.
- d. **Final Effluent Limitation for Total Mercury**
 The final limit for total mercury is the Discharge Specific Level Currently Achievable (LCA) based on a multiple discharger variance from the WQBEL of 1.3 ng/l, pursuant to Rule 1103(9) of the Water Quality Standards. Compliance with the LCA shall be determined as a 12-month rolling average, the calculation of which may be done using blank-corrected sample results. The 12-month rolling average shall be determined by adding the present monthly average result to the preceding 11 monthly average results then dividing the sum by 12. For facilities with quarterly monitoring requirements for total mercury, quarterly monitoring shall be equivalent to three (3) months of monitoring in calculating the 12-month rolling average. Facilities that monitor more frequently than monthly for total mercury must determine the monthly average result, which is the sum of the results of all data obtained in a given month divided by the total number of samples taken, in order to calculate the 12-month rolling average. If the 12-month rolling average for any month is less than or equal to the LCA, the permittees will be considered to be in compliance for total mercury for that month, provided the permittees are also in full compliance with the Pollutant Minimization Program for Total Mercury, set forth in Part I.A.10. of this permit.

The permittee may choose to demonstrate that an alternate site-specific LCA is appropriate and request a permit modification. Such request and supporting documentation shall be submitted in writing to the Department. Supporting documentation shall include a minimum of 12 samples taken over 12-month period in accordance with EPA Method 1631. Upon approval, this permit may be modified in accordance with applicable laws and rules to incorporate the alternate site-specific LCA as the effluent limitation for Total Mercury.

After a minimum of 12 monthly data points have been collected, the permittees may request a reduction in the monitoring frequency for total mercury. This request shall contain an explanation as to why the reduced monitoring is appropriate and shall be submitted to the Department. Upon receipt of written approval and consistent with such approval, the permittees may reduce the monitoring frequency for total mercury indicated in Part I.A.3. of this permit. The Department may revoke the approval for reduced monitoring at any time upon notification to the permittees.

- e. **Total Mercury Testing and Additional Reporting Requirements**
 The analytical protocol for total mercury shall be in accordance with EPA Method 1631, Revision E, "Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Atomic Fluorescence Spectrometry." The quantification level for total mercury shall be 0.5 ng/l, unless a higher level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination.

The use of clean technique sampling procedures is required unless the permittees can demonstrate to the Department that an alternate sampling procedure is representative of the discharge. Guidance for clean technique sampling is contained in EPA Method 1669, Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels (Sampling Guidance), EPA-821-R96-001, July 1996. Information and data documenting the permittee's sampling and analytical protocols and data acceptability shall be submitted to the Department upon request.

In order to demonstrate compliance with EPA Method 1631E and EPA Method 1669, the permittees shall report, on the daily sheet, the analytical results of all field blanks and field duplicates collected in conjunction with each sampling event, as well as laboratory method blanks when used for blank correction. The permittees shall collect at least one (1) field blank and at least one (1) field duplicate per sampling event. If more than ten (10) samples are collected during a sampling event, the permittees shall collect at least one (1) additional field blank AND field duplicate for every ten (10) samples collected. Only field blanks or laboratory method blanks may be used to calculate a concentration lower than the actual sample analytical results (i.e., a blank correction). Only one (1) blank (field OR laboratory method) may be used for blank correction of a given sample result, and only if the blank meets the quality control acceptance criteria. If blank correction is not performed on a given sample analytical result, the permittees shall report under "Total Mercury – Corrected" the same value reported under "Total Mercury – Uncorrected." The field duplicate is for quality control purposes only; its analytical result shall not be averaged with the sample result.

4. Interim Effluent Limitations, Monitoring Point 050A

During the period beginning on the effective date of this permit and lasting until initiation of operation of the RRO Disinfection Project, the permittees are approved to discharge treated municipal wastewater and treated storm water runoff from Monitoring Point 050A through Outfall 050 (RRO). Normally, the discharge may consist of only primary treated effluent when the discharge is necessary due to hydraulic constraints resulting from wet weather events. There shall be no discharge from Monitoring Point 050A unless the discharge from Monitoring Point 049B exceeds a peak hourly flow of 930 MGD (which includes recycle) or in accordance with an approved GLWA WRRF Wet Weather Operational Plan (see Part I.A.11.). Discharge from Outfall 050 (RRO) is not allowed unless hydraulically or structurally necessary. Outfall 050 (RRO) discharges to the Rouge River.

Other options for discharge from Outfall 050 include, 1) when Outfall 049 (DRO) is out-of-service, the discharge may consist of secondary or secondary and primary treated wastewater, 2) when Outfall 049 (DRO) has reduced hydraulic capacity the discharge may consist of secondary or secondary and primary treated wastewater, and 3) when there is department approved limited secondary capacity when Outfall 049 cannot be used due to construction, the discharge may consist of secondary or secondary and primary treated wastewater. Discharges from Monitoring Point 050A shall be limited and monitored by the permittees as specified below.

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>				<u>Maximum Limits for Quality or Concentration</u>				<u>Monitoring Frequency</u>	<u>Sample Type</u>
	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>		

Limitations and monitoring requirements in effect when Outfall 049 is out-of-service and prior to initiation of operation of the RRO Disinfection Project:

All limitations and monitoring specified in Part I.A.1. apply except for the Available Cyanide monitoring requirement, Total Residual Chlorine requirement, and the Fecal Coliform Bacteria limitations, which are replaced with the limitations and monitoring requirements specified below with the Total Residual Chlorine monitoring and limitation removed:

Available Cyanide	---	---	---	---	---	---	89	µg/l	Daily	Grab
Fecal Coliform Bacteria	---	---	---	---	(report)	(report)	---	cts/100 ml	Daily	Grab

a. **Sampling of Short-Term Wet Weather Events**

If the first calendar day of the discharge event through Monitoring Point 050A includes less than three hours of flow but continues into the next calendar day, the sampling can be included as a part of the subsequent event the following day.

4. Interim Effluent Limitations, Monitoring Point 050A (continued)

<u>Parameter</u>	<u>Maximum Limits for Quantity or Loading</u>				<u>Maximum Limits for Quality or Concentration</u>				<u>Monitoring Frequency</u>	<u>Sample Type</u>
	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>		
<u>Limitations and monitoring requirements in effect during other periods of discharge from Monitoring Point 050A and prior to Initiation of operation of the RRO Disinfection Project:</u>										
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	---	---	---	---	40	---	(report)	mg/l	Daily	24-Hr Composite
Total Suspended Solids	---	---	---	---	70	---	(report)	mg/l	Daily	24-Hr Composite
Total Phosphorus (as P)	---	---	---	---	1.5	---	(report)	mg/l	Daily	24-Hr Composite
Available Cyanide	---	---	---	---	---	---	89	µg/l	Daily	Grab
Fecal Coliform Bacteria	---	---	---	---	(report)	---	(report)	cts/100 ml	Daily	Grab
Ammonia Nitrogen (as N)	---	---	---	---	(report)	---	(report)	mg/l	Daily	24-Hr Composite
Total Copper	---	---	---	---	---	---	(report)	µg/l	Daily	24-Hr Composite
Total Polychlorinated Biphenyls (PCBs)										
Aroclor 1016	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1221	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1232	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1242	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1248	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1254	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1260	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
					Maximum PCB					
					Aroclor					
See I.A.4.e.	---	---	---	---	(report)	---	---	µg/l	Monthly	See I.A.4.e.
					Minimum	Maximum				
					Daily	Daily				
pH	---	---	---	---	6.0	9.0	S.U.		Daily	Grab
Dissolved Oxygen	---	---	---	---	(report)	---		mg/l	Daily	Grab

- a. Narrative Standard
The receiving water shall contain no turbidity, color, oil films, floating solids, foams, settleable solids, or deposits as a result of this discharge in unnatural quantities which are or may become injurious to any designated use.
- b. Sampling Locations
The sampling locations for the pollutants in Part 1.A.4. of this permit shall be representative of the effluent and consistent with the locations approved by the Department. The Department may approve alternate sampling locations that are demonstrated by the GLWA to be representative of the effluent.

- c. **Sampling of Short-Term Wet Weather Events**
If the first calendar day of the discharge event through Monitoring Point 050A includes less than three hours of flow but continues into the next calendar day, the sampling can be included as a part of the subsequent event the following day.
- d. **Analytical Methods and Quantification Levels for Available Cyanide and Total Copper**
The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Available Cyanide shall be in accordance with EPA Method OIA-1677. The quantification levels for Available Cyanide and Total Copper shall be 2.0 µg/l and 1.0 µg/l respectively unless a higher level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination. Upon approval of the Department, the permittees may use alternate analytical methods (for parameters with methods specified in 40 CFR 136, the alternate methods are restricted to those listed in 40 CFR 136).
- e. **Limits Below the Quantification Level – Total Polychlorinated Biphenyls (PCBs)** The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Total PCBs shall be in accordance with EPA Method 608.3. Upon approval from the Department, the permittees may use alternate analytical methods (for parameters with methods specified in 40 CFR, Part 136, the alternate methods are restricted to those listed in 40 CFR, Part 136). The quantification level shall be 0.1 ug/l unless a higher level is appropriate because of sample matrix interference. Justification for a higher quantification level shall be submitted to the Department within 30 days of such determination.

For the purpose of reporting on the Daily tab of the DMR, individual aroclor results less than the quantification level shall be reported as "<0.1." This permit condition does not authorize the discharge of PCBs at levels that are injurious to the designated uses of the waters of the state or that constitute a threat to the public health or welfare.

5. Final Effluent Limitations, Monitoring Point 050A

Upon initiation of operation of the RRO Disinfection Project, the permittees are approved to discharge secondary treated municipal wastewater and primary treated municipal wastewater when hydraulically necessary from Monitoring Point 050A through Outfall 050 (RRO). Outfall 050 (RRO) discharges to the Rouge River. Discharge from Outfall 050 (RRO) is approved when the hydraulic capacity of Outfall 049 (DRO) is not sufficient to meet the approved GLWA wet weather operational plan (see Part I.A.11.). Such discharge shall be limited and monitored by the permittees as specified below.

Parameter	Maximum Limits for Quantity or Loading				Maximum Limits for Quality or Concentration				Monitoring Frequency	Sample Type
	Monthly	7-Day	Daily	Units	Monthly	7-Day	Daily	Units		
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Available Cyanide	---	---	---	---	---	---	44	µg/l	Daily	Grab
Total Copper	---	---	---	---	---	---	(report)	µg/l	Monthly	24-Hr Composite
Fecal Coliform Bacteria	---	---	---	---	200	400	---	cts/100 ml	Daily	Grab
Total Residual Chlorine	---	---	---	---	---	---	38	µg/l	Daily	Grab
Oil & Grease	---	---	---	---	---	15	---	mg/l	Daily	Grab
Total Polychlorinated Biphenyls (PCBs)										
Aroclor 1016	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1221	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1232	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1242	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1248	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1254	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Aroclor 1260	---	---	---	---	---	---	(report)	µg/l	Weekly	24-Hr Composite
Maximum PCB Aroclor										
See I.A.5.f.	---	---	---	---	<0.1	---	---	µg/l	Monthly	See I.A.5.f.
Minimum Daily Maximum Daily										
pH	---	---	---	---	6.0	---	9.0	S.U.	Daily	
Dissolved Oxygen	---	---	---	---	3.0	---	---	mg/l	Daily	Grab

- a. Narrative Standard
The receiving water shall contain no turbidity, color, oil films, floating solids, foams, settleable solids, suspended solids, or deposits as a result of this discharge in unnatural quantities which are or may become injurious to any designated use.
- b. Sampling Locations
The sampling locations for the pollutants in Part I.A.5. of this permit shall be representative of the effluent and consistent with the locations approved by the Department. The Department may approve alternate sampling locations that are demonstrated by the permittees to be representative of the effluent.
- c. Sampling of Short-Term Wet Weather Events
If the first calendar day of the discharge event includes less than three hours of flow but continues into the next calendar day, the sampling can be included as part of the subsequent event the following day.

- d. Total Residual Chlorine (TRC)
Compliance with the TRC limit shall be determined on the basis of one or more grab samples. If more than one (1) sample per day is taken, the additional samples shall be collected in near equal intervals over approximately eight (8) hours. The samples shall be analyzed immediately upon collection and the average reported as the daily concentration. Samples shall be analyzed in accordance with Part II.B.2. of this permit.
- e. Analytical Methods and Quantification Levels for Available Cyanide and Total Copper
The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Available Cyanide shall be in accordance with EPA Method OIA-1677. The quantification levels for Available Cyanide and Total Copper shall be 2.0 µg/l and 1.0 µg/l, respectively, unless a higher level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination. Upon approval of the Department, the permittees may use alternate analytical methods (for parameters with methods specified in 40 CFR 136, the alternate methods are restricted to those listed in 40 CFR 136).
- f. Limits Below the Quantification Level – Total Polychlorinated Biphenyls (PCBs)
The sampling procedures, preservation and handling, and analytical protocol for compliance monitoring for Total PCBs shall be in accordance with EPA Method 608.3. Upon approval from the Department, the permittees may use alternate analytical methods (for parameters with methods specified in 40 CFR, Part 136, the alternate methods are restricted to those listed in 40 CFR, Part 136). The quantification level shall be 0.1 ug/l unless a higher level is appropriate because of sample matrix interference. Justification for a higher quantification level shall be submitted to the Department within 30 days of such determination.

The water quality-based effluent limitation for Total PCBs is 2.6×10^{-5} µg/l (2.0×10^{-4} lbs/day) maximum monthly average. This is less than the quantification level. Control requirements are therefore established consistent with R 323.1213. **The discharge of any individual aroclor at or above the quantification level of 0.1 ug/l is a specific violation of this permit.** If concentrations of all aroclors representing a monitoring period are less than their quantification levels, the permittees will be considered to be in compliance with the permit for the monitoring period that the analyses represent, provided that the permittees are also in full compliance with the Pollutant Minimization Program for Total PCBs set forth in Part I.A.10 of this permit. For the purpose of reporting on the Daily tab of the DMR, individual aroclor results less than the quantification level shall be reported as "<0.1." For the purpose of reporting on the Summary tab of the DMR, the value reported under "Maximum PCB Aroclor" shall be the highest aroclor concentration observed during the monitoring period. This permit condition does not authorize the discharge of PCBs at levels that are injurious to the designated uses of the waters of the state or that constitute a threat to the public health or welfare.

- g. Schedule of Implementation
The permittees shall implement the following for Outfall 050 (RRO) Disinfection Program:
- 1) On or before February 1, 2010 (submitted), the permittees shall submit for review and approval a basis of design report for the previously proposed Outfall 084 (RRO2).
 - 2) On or before March 1, 2011 (submitted), the permittees shall submit for review and approval complete plans and specifications for Segment 1 of the previously proposed Outfall 084 (RRO2) project. Segment 1 consists of improvements undertaken at the WRRF consistent with the approved Basis of Design report.
 - 3) On or before July 1, 2012 (submitted), the permittees shall commence construction of Segment 1, consistent with the approved plans and specifications.
 - 4) On or before July 1, 2013 (submitted), the permittees shall submit a construction progress report for Segment 1 of the previously proposed Outfall 084 (RRO2).
 - 5) On or before March 1, 2015, (completed) the permittees shall complete construction of Segment 1 of the previously proposed Outfall 084 (RRO2) project.

- 6) On or before June 1, 2016, (submitted) the permittees shall submit for review and approval a complete basis of design report, and complete plans and specifications, for the Outfall 050 (RRO) Disinfection Project (if design, bid, build). Alternatively, if DWSD chooses to pursue design-build for the Outfall 050 (RRO) Disinfection Project, DWSD shall submit on or before June 1, 2016, (submitted) a detailed engineering report for the overall project, a permitting plan (that includes a description of the construction segments), a timetable for Part 41 permit application submittal, and sufficient project schematics for the overall project.
- 7) On or before November 1, 2016, (completed) the permittees shall submit complete plans and specifications for at a minimum the first segment to be construction under a design-build contract.
- 8) On or before April 1, 2017, (commenced) the permittees shall commence construction of the RRO Disinfection Project, consistent with the approved plans and specifications.
- 9) On or before April 1, 2018, (submitted) the permittees shall submit a construction progress report for RRO Disinfection Project.
- 10) On or before April 1, 2019, (completed) the permittees shall complete construction of RRO Disinfection Project and place into full operation the facilities to achieve final effluent limits specified in Part I.A.5.

6. Combined Sewer Overflow Retention Treatment Basin Discharge Authorization, Monitoring Points 101A, 102A, 103A, 104A, 108A and 109A

During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittees are authorized to discharge treated combined sewage from the Hubbell/Southfield Combined Sewer Overflow (CSO) Retention Treatment Basin (RTB), Monitoring Point 101A, through Outfall 101; from the Puritan/Fenkell CSO RTB, Monitoring Point 102A, through Outfall 102; from the Seven Mile CSO RTB, Monitoring Point 103A, through Outfall 103; from the Belle Isle RTB, Monitoring Point 108A, through Outfall 108; from the Oakwood RTB, Monitoring Point 109A, through Outfall 109; and from the Conner Creek CSO RTB Monitoring Point 104A, through Outfall 104 when the basins are full and wastewater flows exceed downstream interceptor capacity. Outfall 101, Outfall 102, Outfall 103, and Outfall 109 discharge to the Rouge River. Outfall 108 discharges to the Detroit River. Outfall 104 discharges to Conner Creek. Such discharges shall be limited and monitored by the permittees as specified below:

<u>Influent Characteristics</u>	<u>Maximum Limits for Quantity or Loading</u>				<u>Maximum Limits for Quality or Concentration</u>				<u>Monitoring Sample</u>	
	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>7-Day</u>	<u>Event</u>	<u>Units</u>	<u>Frequency</u>	<u>Type</u>
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Effluent Characteristics										
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)	---	---	---	---	(report)	---	(report)	mg/l	Event	Composite
Total Suspended Solids	---	---	---	---	(report)	---	(report)	mg/l	Event	Composite
Ammonia Nitrogen (as N)	---	---	---	---	(report)	---	(report)	mg/l	Event	Composite
Total Phosphorus (as P)	---	---	---	---	(report)	---	(report)	mg/l	Event	Composite
Fecal Coliform Bacteria										
May 1 – October 31	---	---	---	---	---	---	400	cts/100 ml	See I.A.6.a.	Grab
November 1 – April 30	---	---	---	---	---	---	1000	cts/100 ml	See I.A.6.a.	Grab
					<u>Event Average</u>		<u>Event Maximum</u>			
Total Residual Chlorine										
Any Event	---	---	---	---	(report)	---	(report)	mg/l	See I.A.6.a.	Grab
(See additional controls specified in Part I.A.8.)										

Effluent Characteristics	Maximum Limits for Quantity or Loading				Maximum Limits for Quality or Concentration				Monitoring Frequency	Sample Type
	Monthly	7-Day	Daily	Units	Monthly	7-Day	Event	Units		
Oil & Grease (Monitoring Point 109A only)	---	---	---	---	(report)	---	(report)	mg/l	Daily During Discharge	Grab
					<u>Event Minimum</u>		<u>Event Maximum</u>			
pH	---	---	---	---	(report)	---	(report)	S.U.	Daily During Discharge	Grab
Dissolved Oxygen	---	---	---	---	(report)	---	---	mg/l	Daily During Discharge	Grab

a. Retention Basin Monitoring and Reporting

The permittee shall conduct retention basin monitoring and report consistent with the requirements of Part II.C.2. of this permit. The permittee shall supply the results of each sample analyzed during each discharge period.

An Event starts when combined sewage is discharged into a facility, and ends when effluent flow (if any) ceases and does not resume within 24 hours.

Influent flow shall be reported for all wet weather events where combined sewage is discharged into the facility. Influent flow reporting shall also indicate the component of the total influent flow that is dewatered to the interceptor from the facility during an event and shall be reported in the comment section of the monthly Discharge Monitoring Reports (DMR). Alternate procedures may be approved by the Department.

Effluent flow shall be reported for all events that cause discharge from the facility to the receiving waters.

Effluent sampling for CBOD₅, TSS, Ammonia Nitrogen (as N), and Total Phosphorus (as P) shall be by effluent flow-weighted composite sampling over the entire event. Alternate procedures for determining an event composite may be approved by the Department if existing equipment cannot reliably determine a flow-weighted composite. For purposes of reporting for a discharge event that occurs on multiple calendar days, the composite pollutant concentrations for the event shall be reported on the day the discharge event ended. Individual events shall be determined by a lack of effluent discharge for 24 hours.

For **effluent pH**, report the maximum value of any individual sample taken during the month in the "Maximum" column under "Quality or Concentration" on the monthly DMRs and the minimum value of any individual sample taken during the month in the "Minimum" column under "Quality or Concentration" on the monthly DMRs. The individual values taken during the month shall be reported on the daily DMRs.

For **effluent dissolved oxygen**, report the lowest concentration of any individual sample in the "Minimum" column under the "Quantity or Concentration" on the monthly DMRs. The individual values taken during the month shall be reported on the daily DMRs.

For **effluent Fecal Coliform Bacteria and Total Residual Chlorine**, grab samples shall be collected every two (2) hours for the first six (6) hours of the discharge and every four (4) hours thereafter for the duration of the discharge; the first sample shall be collected as soon as practical after the discharge begins. For fecal coliform, the "event maximum" shall be reported on the daily DMRs as the geometric mean of all samples taken during an event, provided that three (3) or more samples are collected. For TRC, report the average of all samples in an event as the "Event Average" and the maximum individual sample in an event as the "Event Maximum" on the daily DMRs. The goal of the effluent sampling program is to collect at least three samples during each discharge event, and samples shall be collected at shorter intervals at the onset of the event, if the permittee estimates that the event duration may be less than six hours. For purposes of reporting for a discharge event that occurs on multiple calendar days, the pollutant concentrations for the event shall be reported on the day the discharge event ended. The highest event averages for Fecal Coliform and TRC shall also be reported in the "Maximum" columns under "Quality and Concentration" on the monthly DMRs.

b. Retention Treatment Basin Dewatering

The retention treatment basin shall be promptly dewatered as in accordance with the Department Approved Consolidated Annual Report following the need to divert flow to the basin and shall be maintained in readiness for use. The discharge of sludge or residual accumulations from the basin to the surface waters is prohibited. These sludges shall be promptly removed and disposed in accordance with procedures approved by the Department.

For this permit while the Regional Operational Plan is being revised, if up to 930 MGD (including recycle) is being processed with secondary treatment at the WRRF and no primary flow is being discharged, then tributary combined or sanitary storage basins in the GLWA system may be dewatered. Such dewatering will not be considered a violation of this permit, even if contrary to the Wet Weather Event definition (see Part II.A.). Once a revised Regional Operation Plan is developed, it shall be implemented once reviewed and approved by the Department.

c. Narrative Standard

The receiving water shall contain no turbidity, color, oil films, floating solids, foams, settleable solids, or deposits as a result of this discharge in unnatural quantities which are or may become injurious to any designated use.

d. Operation and Maintenance Plan

The permittee shall assure that discharges only occur in response to rainfall (or snowmelt) events and cease soon thereafter. Any rehabilitation and maintenance needs shall be addressed to ensure adequate sewer capacity and functionality. This may be accomplished through continued implementation of the approved Operation and Maintenance Plan.

7. Combined Sewer Overflow Screening and Disinfection Facilities Discharge Authorization, Monitoring Points 105A, 106A and 107A

During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittees are authorized to discharge treated combined sewage from the Leib Combined Sewer Overflow (CSO) Screening and Disinfection Facility Monitoring Point 105A through Outfall 105, from the St. Aubin CSO Screening and Disinfection Facility Monitoring Point 106A through Outfall 106, and from the Baby Creek CSO Screening and Disinfection Facility Monitoring Point 107A through Outfall 107 when the wastewater flows exceed downstream interceptor capacities. Outfall 105 and Outfall 106 discharge to the Detroit River. Outfall 107 discharges to the Rouge River. Such discharges shall be limited and monitored by the permittees as specified below:

<u>Effluent Characteristics</u>	<u>Maximum Limits for Quantity or Loading</u>				<u>Maximum Limits for Quality or Concentration</u>				<u>Monitoring Frequency</u>	<u>Sample Type</u>
	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>	<u>Monthly</u>	<u>7-Day</u>	<u>Daily</u>	<u>Units</u>		
Flow	(report)	---	(report)	MGD	---	---	---	---	Daily	Report Total Daily Flow
Carbonaceous Biochemical Oxygen Demand (CBOD5)	---	---	---	---	(report)	---	(report)	mg/l	Quarterly	Grab
Total Suspended Solids	---	---	---	---	(report)	---	(report)	mg/l	Quarterly	Grab
Ammonia Nitrogen (as N)	---	---	---	---	(report)	---	(report)	mg/l	Quarterly	Grab
Total Phosphorus (as P)	---	---	---	---	(report)	---	(report)	mg/l	Quarterly	Grab
Oil & Grease (Baby Creek CSO Screening & Disinfection Facility, only)	---	---	---	---	(report)	---	(report)	mg/l	Daily During Discharge	Grab
							<u>Event Maximum</u>			
Fecal Coliform Bacteria										
May 1 – October 31	---	---	---	---	---	---	400	cts/100 ml	See I.A.7.a.	Grab
November 1 – April 30	---	---	---	---	---	---	1000	cts/100 ml	See I.A.7.a.	Grab
					<u>Event Average</u>		<u>Event Maximum</u>			
Total Residual Chlorine Any Event (see additional controls specified in Part 1.A.8.)	---	---	---	---	(report)	---	(report)	mg/l	See I.A.7.a.	Grab
					<u>Event Minimum</u>		<u>Event Maximum</u>			
pH	---	---	---	---	(report)	---	(report)	S.U.	Daily During Discharge	Grab
Dissolved Oxygen	---	---	---	---	(report)	---	---	mg/l	Daily During Discharge	Grab

- a. Screening and Disinfection Facilities Monitoring and Reporting
The permittees shall monitor screening and disinfection facilities performance and report the monitoring consistent with the requirements of Part II.C.2. of this permit. The permittees shall supply the results of each sample taken during each discharge period.

Effluent flow shall be reported for all events that cause discharge from the facility to the receiving waters.

For **effluent pH**, report the maximum value of any individual sample taken during the month in the "Maximum" column under "Quality or Concentration" on the monthly DMRs and the minimum value of any individual sample taken during the month in the "Minimum" column under "Quality or Concentration" on the monthly DMRs. The individual values taken during the month shall be reported on the daily DMRs.

For **effluent dissolved oxygen**, report the lowest concentration of any individual sample in the "Minimum" column under the "Quantity or Concentration" on the monthly DMRs. The individual values taken during the month shall be reported on the daily DMRs.

For **effluent Fecal Coliform Bacteria and Total Residual Chlorine**, grab samples shall be collected every two (2) hours for the first six (6) hours of the discharge and every four (4) hours thereafter for the duration of the discharge; the first sample shall be collected as soon as practical after the discharge begins. For fecal coliform, the "event maximum" shall be reported on the daily DMRs as the geometric mean of all samples taken during an event, provided that three (3) or more samples are collected. For TRC, report the average of all samples in an event as the "Event Average" and the maximum individual sample in an event as the "Event Maximum" on the daily DMRs. The goal of the effluent sampling program is to collect at least three samples during each discharge event, and samples shall be collected at shorter intervals at the onset of the event, if the permittees estimate that the event duration may be less than six hours. For purposes of reporting for a discharge event that occurs on multiple calendar days, the pollutant concentrations for the event shall be reported on the day the discharge event ended. The highest event averages for Fecal Coliform and TRC shall also be reported in the "Maximum" columns under "Quality and Concentration" on the monthly DMRs.

- b. **Narrative Standard**
The receiving water shall contain no turbidity, color, oil films, floating solids, foams, settleable solids, or deposits as a result of this discharge in unnatural quantities which are or may become injurious to any designated use.
- c. **Sampling Locations**
The sampling locations for the pollutants indicated in Part I.A.7 of this permit shall be representative of the effluent and consistent with the locations approved by the Department.
- d. **Operation and Maintenance Plan**
The permittees shall assure that discharges only occur in response to rainfall (or snowmelt) events and cease soon thereafter. Any rehabilitation and maintenance needs shall be addressed to ensure adequate sewer capacity and functionality. This may be accomplished through continued implementation of the approved Operation and Maintenance Plan.
- e. **Treatment Facility Dewatering**
The treatment facility shall be promptly dewatered (if applicable) in accordance with the Department Approved Consolidated Annual Report possible following the need to divert flow to the facility and shall be maintained in readiness for use. The discharge of sludge or residual accumulations from the facility to the surface waters is prohibited.

For this permit while the Regional Operational Plan is being revised, if up to 930 MGD (including recycle) is being processed with secondary treatment at the WRRF and no primary flow is being discharged, then tributary combined or sanitary storage basins in the GLWA system may be dewatered. Such dewatering will not be considered a violation of this permit, even if contrary to the Wet Weather Event definition (see Part II.A). Once a revised Regional Operation Plan is developed, it shall be implemented once reviewed and approved by the Department.

8. Total Residual Chlorine Minimization Program

The goal of the Total Residual Chlorine (TRC) Minimization Program is operate the CSO RTBs and the CSO screening and disinfection facilities in a manner that will provide consistent, effective disinfection while minimizing the discharge of TRC, recognizing the overall goal is compliance with the TRC Final Acute Value of 0.038 mg/l at any point in the receiving stream, unless it is determined by the Department by a permit action that a higher level is acceptable.

In addition, the Operational Goals for this facility are 1.5 mg/l TRC as an event average value and 2.0 mg/l (November – April) or 3.0 mg/l (May – October) TRC as an event instantaneous maximum value.

a. TRC Minimization Assessment (Assessment) (submitted)

The permittees shall prepare and conduct a program to assess the capability of each of the 5 CSO RTBs and screening and disinfection facilities as agreed to (a subset of those listed in Part I.A.6. and Part I.A.7.), to minimize the discharge of TRC. Each Assessment shall be conducted according to a schedule acceptable to the Department. Compliance with the Fecal Coliform Bacteria effluent limits set forth in Part I.A.6. and Part I.A.7. of this permit shall be maintained during each Assessment. Each Assessment shall include an evaluation of various operational practices under a variety of wet weather events to identify measures which can be taken to reduce TRC discharge concentrations. Upon notification by the Department, the permittees shall begin conducting each Assessment over an 18-month period and shall submit a report summarizing the results to the Department within 60 days of completion. An extension of an Assessment period beyond 18 months may be requested by the permittees for approval by the Department in the event that a sufficient number of CSO discharge events have not occurred to allow for an adequate assessment of operational procedures.

Each Assessment report shall include the expected achievable TRC discharge concentrations, recommendations as to specific protocols to be used to manage sodium hypochlorite (NaOCl) dosage rates under various conditions to achieve the Operational Goals, and recommended facility modifications to enhance the ability to control TRC levels while maintaining compliance with the Fecal Coliform Bacteria limits. Specific procedures for adjustment of NaOCl feed rates to minimize the discharge of TRC shall be submitted as part of the Operational Plan (and revised as appropriate in annual updates), as required by Part I.A.15.e. of this permit. The TRC minimization procedures, developed as part of each Assessment, shall be implemented upon approval by the Department.

b. Operational Goals

Upon completion of each Assessment, the permittees shall operate the facility with a goal of 1.5 mg/l TRC as an event average value and a goal of 2.0 mg/l (November – April) or 3.0 mg/l (May – October) TRC as an event instantaneous maximum value. If upon completion of an Assessment, the permittees determine the facility can achieve lower TRC goals than those specified above, then the permittees shall operate the facility to achieve the lower TRC levels. If either TRC goal is exceeded for a CSO discharge event, the permittees shall submit a written report to the Department within seven (7) days explaining the cause of the exceedance and describing the corrective measures that will be undertaken to prevent a future recurrence.

c. In-Stream TRC Effluent Plume Evaluation (submitted)

The permittees shall conduct an evaluation of the in-stream TRC effluent plume attributable to each of the agreed-to 5 CSO RTBs screening and disinfection facility discharges. The evaluation shall identify the location and size of the TRC effluent plume during and after CSO discharge events and identify the maximum TRC concentrations in-stream at various downstream locations. Upon notification by the Department to begin conducting each Assessment (Part I.A.8.a.), the permittees shall have 60 days to submit a TRC effluent plume work plan describing the proposed evaluation including sampling locations and a proposed implementation schedule such that the In-Stream TRC Effluent Plume Evaluation shall occur after completion of each Assessment and when the operational goals begin. The permittees shall implement the In-Stream TRC Effluent Plume Evaluation following the schedule upon Department approval of the TRC effluent plume work plan. The permittees shall submit a report documenting the results of the TRC Effluent Plume Evaluation within 90 days after completion of the field work.

d. Permit Re-Opener Clause

Upon completion of each TRC Minimization Assessment and each In-Stream TRC Effluent Plume Evaluation, the Department may reevaluate the need for TRC effluent limitations. This permit may be

modified in accordance with applicable laws and rules to incorporate such revisions as may be necessary to comply with Water Quality Standards at the time of discharge.

- e. Best Management Practices/Operator Coordination Work Group (Work Group)
The permittees shall attend and participate in at least quarterly Work Group meetings with representatives from other CSO facilities in Southeast Michigan to exchange information and share experiences relating to the operation and maintenance of CSO control facilities. Such Work Group meetings shall be used to develop Best Management Practices (BMPs) relating to CSO RTB operation, with an initial focus on actions to minimize the TRC discharge levels. At a minimum, the Work Group shall include representatives of the following CSO facilities: Birmingham CSO RTB, Bloomfield Village CSO RTB, Dearborn CSO, GLWA WRRF CSO Facilities, Inkster-Dearborn Heights CSO, Oakland County-Acacia Park (Acacia Park CSO Drainage District, Village of Beverly Hills, City of Birmingham), Redford Township CSO, River Rouge CSO, Wayne County – Dearborn Heights CSO, Wayne County – Inkster CSO, Wayne County – Inkster – Dearborn Heights CSO, and Wayne County – Redford – Livonia CSO. The Work Group shall submit an annual report summarizing the meetings and BMPs developed to the Department by March 1st of each year.

9. Additional Monitoring Requirements

As a condition of this permit, the permittees shall monitor the discharge from monitoring points 049F and 050A for the constituents identified below. This monitoring is an application requirement of 40 CFR 122.21(j), effective December 2, 1999. Testing shall be conducted in October 2019, May 2020, March 2021, and August 2021. Grab samples shall be collected for total phenols, and the Volatile Organic Compounds identified below. For all other parameters, 24-hour composite samples shall be collected.

Test species for whole effluent toxicity monitoring shall include fathead minnow **and** *Ceriodaphnia dubia*. If the permittees have received Department approval to conduct chronic toxicity testing using the more sensitive species identified in the toxicity database, the first three (3) tests required above may be performed using the more sensitive species. The last (4th) test shall be conducted using both species. Testing and reporting procedures shall follow procedures contained in EPA-821-R-02-013, "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms" (Fourth Edition). When the effluent ammonia nitrogen (as N) concentration is greater than 3 mg/l, the pH of the toxicity test shall be maintained at a pH of 8 Standard Units. Acute and chronic toxicity data shall be included in the reporting for the toxicity test results. Toxicity test data acceptability is contingent upon the validation of the test method by the testing laboratory. Such validation shall be submitted to the Department upon request.

For selected parameters required under this section, the maximum acceptable quantification levels and analytical methods shall be as specified under Quantification Levels and Analytical Methods for Selected Parameters, below, unless a higher quantification level is appropriate because of sample matrix interference. Justification for higher quantification levels shall be submitted to the Department within 30 days of such determination.

The results of such additional monitoring shall be submitted with the application for reissuance (see the cover page of this permit for the application due date). The permittees shall notify the Department within 14 days of completing the monitoring for each month specified above in accordance with Part II.C.5. Additional reporting requirements are specified in Part II.C.11. The permittees shall report to the Department any whole effluent toxicity test results greater than 1.0 TU_A or 1.0 TU_C within five (5) days of becoming aware of the result. If, upon review of the analysis, it is determined that additional requirements are needed to protect the receiving waters in accordance with applicable water quality standards, the permit may then be modified by the Department in accordance with applicable laws and rules.

Whole Effluent Toxicity
chronic toxicity

Hardness
calcium carbonate

Metals (Total Recoverable), Cyanide and Total Phenols

antimony	arsenic	barium	
beryllium	boron	cadmium	chromium
copper	lead	nickel	
selenium	silver	thallium	zinc
total phenolic compounds			

Volatile Organic Compounds

acrolein	acrylonitrile	benzene	bromoform
carbon tetrachloride	chlorobenzene	chlorodibromomethane	chloroethane
2-chloroethylvinyl ether	chloroform	dichlorobromomethane	1,1-dichloroethane
1,2-dichloroethane	trans-1,2-dichloroethylene	1,1-dichloroethylene	1,2-dichloropropane
1,3-dichloropropylene	ethylbenzene	methyl bromide	methyl chloride
methylene chloride	1,1,2,2,-tetrachloroethane	tetrachloroethylene	toluene
1,1,1-trichloroethane	1,1,2-trichloroethane	trichloroethylene	vinyl chloride

Acid-Extractable Compounds

4-chloro-3-methylphenol	2-chlorophenol	2,4-dichlorophenol	2,4-dimethylphenol
4,6-dinitro-o-cresol	2,4-dinitrophenol	2-nitrophenol	4-nitrophenol
Pentachlorophenol	phenol	2,4,6-trichlorophenol	

Base/Neutral Compounds

acenaphthene	acenaphthylene	anthracene	benzidine
benzo(a)anthracene	benzo(a)pyrene	3,4-benzofluoranthene	benzo(ghi)perylene
benzo(k)fluoranthene	bis(2-chloroethoxy)methane	bis(2-chloroethyl)ether	bis(2-chloroisopropyl)ether
bis(2-ethylhexyl)phthalate	4-bromophenyl phenyl ether	butyl benzyl phthalate	2-chloronaphthalene
4-chlorophenyl phenyl ether	chrysene	di-n-butyl phthalate	di-n-octyl phthalate
dibenzo(a,h)anthracene	1,2-dichlorobenzene	1,3-dichlorobenzene	1,4-dichlorobenzene
3,3'-dichlorobenzidine	diethyl phthalate	dimethyl phthalate	2,4-dinitrotoluene
2,6-dinitrotoluene	1,2-diphenylhydrazine	fluoranthene	fluorene
Hexachlorobenzene	hexachlorobutadiene	hexachlorocyclo-pentadiene	hexachloroethane
indeno(1,2,3-cd)pyrene	isophorone	naphthalene	nitrobenzene
n-nitrosodi-n-propylamine	n-nitrosodimethylamine	n-nitrosodiphenylamine	phenanthrene
pyrene	1,2,4-trichlorobenzene		

Quantification Levels and Analytical Methods for Selected Parameters

Parameter	Quantification Level	Analytical Method
1,2-Diphenylhydrazine (as Azobenzene)	3.0 ug/l	
2,4,6-Trichlorophenol	5.0 ug/l	
2,4-Dinitrophenol	19 ug/l	
3,3'-Dichlorobenzidine	1.5 ug/l	EPA Method 605
4-chloro-3-methylphenol	7.0 ug/l	
4,4'-DDD	0.05 ug/l	EPA Method 608
4,4'-DDE	0.01 ug/l	EPA Method 608
4,4'-DDT	0.01 ug/l	EPA Method 608
Acrylonitrile	1.0 ug/l	
Aldrin	0.01 ug/l	EPA Method 608
Alpha-Hexachlorocyclohexane	0.01 ug/l	EPA Method 608
Antimony, Total	1 ug/l	
Arsenic, Total	1 ug/l	
Barium, Total	5 ug/l	
Benidine	0.1 ug/l	EPA Method 605
Beryllium, Total	1 ug/l	
Beta-Hexachlorocyclohexane	0.01 ug/l	EPA Method 608

Parameter	Quantification Level	Analytical Method
Bis (2-Chloroethyl) Ether	1.0 ug/l	
Boron, Total	20 ug/l	
Cadmium, Total	0.2 ug/l	
Chlordane	0.01 ug/l	EPA Method 608
Chromium, Hexavalent	5 ug/l	
Chromium, Total	10 ug/l	
Copper, Total	1 ug/l	
Cyanide, Available	2 ug/l	EPA Method OIA 1677
Cyanide, Total	5 ug/l	
Delta-Hexachlorocyclohexane	0.01 ug/l	EPA Method 608
Dieldrin	0.01 ug/l	EPA Method 608
Di-N-Butyl Phthalate	9.0 ug/l	
Endosulfan I	0.01 ug/l	EPA Method 608
Endosulfan II	0.01 ug/l	EPA Method 608
Endosulfan Sulfate	0.01 ug/l	EPA Method 608
Endrin	0.01 ug/l	EPA Method 608
Endrin Aldehyde	0.01 ug/l	EPA Method 608
Fluoranthene	1.0 ug/l	
Heptachlor	0.01 ug/l	EPA Method 608
Heptachlor Epoxide	0.01 ug/l	EPA Method 608
Hexachlorobenzene	0.01 ug/l	EPA Method 612
Hexachlorobutadiene	0.01 ug/l	EPA Method 612
Hexachlorocyclopentadiene	0.01 ug/l	EPA Method 612
Hexachloroethane	5.0 ug/l	
Lead, Total	1 ug/l	
Lindane	0.01 ug/l	EPA Method 608
Lithium, Total	10 ug/l	
Mercury, Total	0.5 ng/l	EPA Method 1631E
Nickel, Total	5 ug/l	
PCB-1016	0.1 ug/l	EPA Method 608.3
PCB-1221	0.1 ug/l	EPA Method 608.3
PCB-1232	0.1 ug/l	EPA Method 608.3
PCB-1242	0.1 ug/l	EPA Method 608.3
PCB-1248	0.1 ug/l	EPA Method 608.3
PCB-1254	0.1 ug/l	EPA Method 608.3
PCB-1260	0.1 ug/l	EPA Method 608.3
Pentachlorophenol	1.8 ug/l	
Perfluorooctane sulfonate (PFOS)	2.0 ng/l	ASTM D7979 or an isotope dilution method (sometimes referred to as Method 537 modified)
Perfluorooctanoic acid (PFOA)	2.0 ng/l	ASTM D7979 or an isotope dilution method (sometimes referred to as Method 537 modified)
Phenanthrene	1.0 ug/l	
Selenium, Total	1.0 ug/l	

Parameter	Quantification Level	Analytical Method
Silver, Total	0.5 ug/l	
Strontium, Total	1000 ug/l	
Sulfide, Dissolved	20 ug/l	
Thallium, Total	1 ug/l	
Toxaphene	0.1 ug/l	EPA Method 608
Vinyl Chloride	0.25 ug/l	
Zinc, Total	10 ug/l	

10. Pollutant Minimization Program for Total Mercury and PCBs

The goal of the Pollutant Minimization Program is to maintain the effluent concentration of total mercury at or below 1.3 ng/l and the final effluent limitations for Total Polychlorinated Biphenyls (PCBs). The permittees shall continue to implement the Pollutant Minimization Program approved on November 9, 1995, and updated in October, 1996, and modifications thereto, to proceed toward the goal. The Pollutant Minimization Program includes the following:

- a. an annual review and semi-annual monitoring of potential sources of mercury and PCBs entering the wastewater collection system, including wet weather sources such as runoff/contributions from contaminated sites in the collection area;
- b. a program for quarterly monitoring of influent and periodic monitoring of sludge for mercury and PCBs; and
- c. implementation of reasonable cost-effective control measures when sources of mercury and/or PCBs are discovered. Factors to be considered include significance of sources, economic considerations, and technical and treatability considerations.

On or before October 1st of each year, the permittees shall submit a status report for the previous calendar year to the Department that includes 1) the monitoring results for the previous year, 2) an updated list of potential mercury and/or PCB sources, and 3) a summary of all actions taken to reduce or eliminate identified sources of mercury and/or PCBs.

Any information generated as a result of the Pollutant Minimization Program set forth in this permit may be used to support a request to modify the approved program or to demonstrate that the Pollutant Minimization Program requirement has been completed satisfactorily.

A request for modification of the approved program and supporting documentation shall be submitted in writing to the Department for review and approval. The Department may approve modifications to the approved program (approval of a program modification does not require a permit modification), including a reduction in the frequency of the requirements under items a. and b.

This permit may be modified in accordance with applicable laws and rules to include additional mercury and/or PCB conditions and/or limitations as necessary.

11. Water Resource Recovery Facility Wet Weather Operational Plan

The approved Water Resource Recovery Facility Wet Weather Operational Plan provides the protocol for operations during the interim period before full completion of the Long-term CSO Control Plan. This plan details the necessary requirements to maximize wet weather treatment at the WRRF, while complying with effluent limits and all other conditions of this permit, and minimizing untreated combined sewage discharges in the tributary collection system.

The GLWA WRRF Wet Weather Operational Plan shall be coordinated with the Collection System and CSO Treatment Facilities Operational Plan that is required in accordance with Part I.A.15.d. of this permit. Annually, on or before April 1st, the permittees shall submit an update of the Water Resource Recovery Facility Wet Weather Operational Plan in conjunction with the Collection System and CSO Treatment Facilities Operational Plan update as part of the Consolidated Annual Report to the Department for review and approval.

12. Facilities Improvement Program

The permittees shall continue to meet the sludge dewatering, conveyance, and final disposal requirements; submit and implement the solids disposal plans; correct the alum sludge issue; submit the WRRF shutdown schedules; and develop and implement the asset management program as detailed below.

a. WRRF Solids Processing Requirements and Corrections

- 1) Capacity for sludge dewatering, conveyance, and final disposal; Required maximum solids inventory loads.

The permittees shall ensure that sludge dewatering equipment, sludge conveyance equipment, and final sludge disposal capability is available at the GLWA WRRF as follows:

- a) The permittees shall ensure that the WRRF sludge dewatering equipment, sludge conveyance equipment, and final sludge disposal capability are maintained for use; and in good operational working order to meet the following requirements:
 - (1) Average capacity of 500 dry tons per day (dtpd), calculated as a calendar monthly average;
 - (2) Peak capacity of 850 dtpd, calculated as a 10-day average;
 - (3) The peak 10-day average shall be available during any wet weather event when the WRRF is operated in the "Storm Period" of the currently approved WRRF Wet Weather Operational Plan as required by Part I.A.11.

The permittees shall also:

- (4) Notify the Department within one business day if solids are recycled from the gravity thickeners to the head of the WRRF for more than 72 hours and provide an explanation for the recycled solids. Recycled solids are defined as a TSS overflow concentration of 1000 mg/l or greater from Complex A thickeners;
- (5) Maintain a monthly average solids inventory of less than 750 dtpd, when there are less than 5 days of discharge from Outfall 049A during the month, and maintain a calendar quarterly average solids inventory not to exceed 1000 dtpd. Solids inventory is defined as the total solids in gravity thickener complexes A and B, determined daily in dtpd;
- (6) This Section will be reviewed during the next NPDES reissuance based on WRRF performance; and
- (7) The permittees are allowed to submit to the Department for review and approval a request to modify the numerical levels specified in Part I.A.12.a. of this permit. This modification request shall include supporting rationale for the revised numerical levels.

2) Long-Term Solids Disposal Plan

- a) The permittees submitted to the Department for review and approval a Long-Term Solids Disposal Plan (LTSDP). This Solids Disposal Plan is designed to ensure the availability of sufficient sludge dewatering equipment and sludge disposal capability to meet the capacity requirements specified in Parts I.A.12.a.1).a).(1)&(2) of this permit. The permittees shall implement the LTSDP in accordance with the following schedule:

- (1) On or before December 31, 2018, (submitted) the permittees shall submit for approval, a disposal plan for 250 dtpd. This requirement is based on the LTSDP approved on September 24, 2013. Upon notification from the Department, the permittees shall implement the approved disposal plan;
- (2) On or before December 31, 2025, the permittees shall complete implementation of the approved plan referenced in item (1) above;

- b) The GLWA are advised that implementation of individual elements of the LTSDP may require Part 41 wastewater construction permits or may require other Department approvals.

3) Alum Sludge Correction

The permittees shall continue to implement the approved plan to correct the solids dewatering concerns at the WRRF due to alum sludge discharges from GLWA water treatment plants (WTPs) into the collection system.

Annually, on or before September 1st the permittees shall submit a report to the Department describing if the implemented plan continued to meet the conditions specified above for the preceding fiscal year (July 1 – June 30).

Part 41 construction permits at the WRRF and/or Act 399 construction permits at the specific WTPs may be needed depending on the components of the approved plan.

b. WRRF Quarterly Shutdown Schedules

On or before December 1, March 1, June 1, and September 1, the permittees shall submit quarterly WRRF Shutdown Schedules, until notified in writing by the Department. Consistent with the quarterly dates indicated above, these schedules shall be submitted to the Department in a mutually agreeable format one month prior to the start of each calendar quarter for review and approval. Each quarterly schedule shall detail the primary treatment capacity, secondary treatment capacity, and sludge processing capacity that is planned to be available during the upcoming quarter, considering coordinated shutdowns necessary to complete all rehabilitation and other projects. The shutdown schedules shall be proposed to minimize environmental impact and maximize available treatment during construction of all projects, consistent with the requirements of the rules associated with Act 451, Part 41, being 299.2943 and 299.2955(1) and (3).

c. Operation, Maintenance & Replacement/Asset Management

The permittees shall at all times properly operate and maintain all facilities (i.e., sewer system, treatment works, as defined in Part 41 of Act 451, 1994 as amended, and control systems) that are installed or used by the permittees to operate the treatment works and sewer system and achieve and maintain compliance with the conditions of this permit. The requirements of an asset management program contain goals of effective performance, adequate funding, and adequate operator staffing and training. Asset management is a planning process focused on gaining optimum value for each asset and providing the financial resources to rehabilitate and replace them when necessary; Asset management is centered on a framework of five (5) core elements: the current state of the assets, the required sustainable level of service, the assets critical to sustained performance, the best-value life-cycle costs, and the best long-term funding strategy.

- 1) The permittees shall continue to implement the approved Asset Management Program that addresses the following items:

- A comprehensive fixed asset inventory that is maintained, managed, and updated within a computerized maintenance management system (CMMS),

- A comprehensive inventory of the collection system fixed assets and collection system map,
- A Preventive Maintenance Program that may include predictive and reliability centered maintenance,
- A Needs Assessment updated every five years as part of the Project Plan (due on or before October 1, 2021), including condition assessment and evaluation of service level,
- An assessment of asset criticality and risk management,
- A capital planning process,
- A Scheduled Replacement Program (SRP) for assets,
- Monitoring and periodic performance evaluation through Key Performance Indicators (KPIs),
- Management oversight of system performance.

The permittees' Asset Management Program submitted on January 1, 2014, was approved on January 14, 2014, and substantially revised on September 29, 2017.

2) An Annual Report covering implementation of the Asset Management Program during the prior Fiscal Year (July 1 – June 30) shall be prepared by the permittees and submitted to the Department on or before October 1st. The Annual Report shall include:

- a) A description and evaluation of the sufficiency of the staffing levels maintained during the year,
- b) A description and evaluation of the sufficiency and adequacy of inspections and maintenance activities conducted and corrective actions taken during the previous year,
- c) Expenditures for collection system maintenance activities, treatment works maintenance activities, corrective actions, and capital investment during the previous year, compared with budgeted/projected expenditures, including an evaluation of the sufficiency of expenditures,
- d) A summary of asset/areas identified for inspection/action (including capital improvement) in the upcoming year based on the five (5) core elements and the criticality and risk analysis,
- e) A maintenance budget and capital improvement budget for the upcoming year, based on implementation of an effective asset management program that meets the five (5) core elements,
- f) An updated estimate of the revenue necessary to complete anticipated OM&R activities, the associated rate schedule impact, and an assessment of the adequacy of the revenue to perform necessary OM&R work, and
- g) A description of the progress made towards completion of the outstanding tasks as described in the previous year's Asset Management Annual Report and an updated schedule for completion of any outstanding tasks.

d. Staffing Plan

A Staffing Plan, as required by ACO-00131, has been approved by the Department. The GLWA shall provide an adequate staffing level, in accordance with the approved Staffing Plan, to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit. During the term of ACO-00131, a change in the minimum staffing level may be requested by the GLWA by submittal of a revised Staffing Plan, including training requirements, and may be revised only by mutual agreement in writing between the GLWA and the Department. Should ACO-00131 be terminated, then the staffing plan shall be updated as required by the Operations and Maintenance Manual (Part II.C.14 of this permit), and an up to date copy of the manual shall be kept at the WRRF. The Department may review the manual in whole or in part (i.e. staffing) at their discretion and require modifications to it if portions are determined to be inadequate.

- e. Key Performance Indicator Monthly Report
The permittee shall update the Key Performance Indicator (KPI) report monthly. If Administrative Consent Order No. ACO-000131, as amended, is terminated, the KPI report shall be submitted by the last day of the month following the termination of the ACO.
- f. Public Participation
The permittees will participate in Department initiated public outreach meetings during the term of this permit as resources allow and provided there is adequate notification by the Department.


13. Reopener for Primary and Secondary Treatment Capacity

The permittees are required to maintain a wet weather primary treatment capacity of 1700 MGD (raw) and wet weather secondary treatment capacity of 930 MGD (which includes recycle). When the elevation of the influent wet well is greater than 85 feet and the facility is not pumping at 1700 MGD (raw), the discharge from untreated combined sewage overflow (CSO) upstream of the facility are not authorized, unless caused by localized storm conditions.


These required wet weather treatment capacities may be revised if new/altered wet weather conditions (such as initiation of operation of upstream CSO facilities, etc.) indicate that either less or more flow can be effectively processed. The criteria used to determine whether the required wet weather primary treatment capacities should be revised must include additional plant evaluation under the updated conditions, using testing procedures approved by the Department.

For reference, outfall/monitoring point designations are shown on the following diagrams:

Prior to Initiation of Operation of RRO Disinfection Project



After Initiation of Operation of RRO Disinfection Project



14. Outfalls Prohibited from Discharge to Combined Sewer System

The following Outfalls are prohibited from discharge except as provided for in Part II.C.9.:

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
004	Fairview (DWF) Pump Station (P28 through P31) Parkview & Detroit River - Emergency only	42°21'20" 082°58'01"	Discharge to Detroit River (Stop-logged)
014	Dubois (B12) Dubois & Detroit River	42°20'01" 083°01'19"	Detroit River
051	Carbon (B46) Carbon & Rouge River	42°17'07" 083°08'17"	Rouge River
054	Fort St. (DWSD Northwest) Interceptor) (B50) South Fort St. & Rouge River (West Shore)	42°17'25" 083°08'35"	Rouge River
056	Fort St. (Oakwood District) (B49) South Fort St. & Rouge River (West Shore)	42°17'27" 083°08'33"	Rouge River
080	Fox Creek Backwater Gates (B01) East Jefferson & Fox Creek.	42°22'28" 082°56'27"	Fox Creek to Detroit River

The permittees shall provide for ongoing monitoring (Flow, Duration) for these outfalls should they discharge. This monitoring shall be used to comply with the requirements of Section 324.3112(a) of The Michigan Act (See Part I.A.16.).

15. Discharges from Combined Sewer System

a. Limited Discharge Authorization

The permittees are required to utilize, to the maximum extent practicable, available sewerage system transportation capabilities for the delivery of combined sewage to treatment facilities. For an interim period during which the amended Long-Term CSO Control Plan is to be implemented, the permittees are authorized to discharge during wet weather events (see Part II.A.) combined sewage from the outfalls and locations listed below in accordance with the following conditions:

- 1) a flow rate equivalent to the peak dry weather flow rate has been conveyed to the secondary treatment facilities for treatment without bypass,
- 2) the total sewerage system storage and transportation capacity for conveyance of wet weather flows to the treatment facilities for treatment has been utilized within the hydraulic design constraints of the system,
- 3) all primary treatment plant capacity and secondary treatment plant capacity has been utilized in accordance with the approved WRRF Wet Weather Operation Plan (Part 1.A.11.), unless a storm event is localized to the extent that the hydraulic capacity of a portion of the collection system (considering storage) is exceeded prior to reaching plant capacities, and
- 4) the permittees are in full compliance with all requirements as set forth in Part I.A.16. Combined Sewer Overflow discharges to the Rouge River, the Detroit River, and the Old Channel of the Rouge River are authorized until prohibited, eliminated, or adequately treated to meet water quality standards at times of discharge in accordance with the requirements below, and as specified in Part 1.A.15.f. and g.
- 5) the outfalls that immediately follow this paragraph are included in the Limited Discharge Authorization. There are some untreated CSO outfalls that appear to discharge only during extreme events. Extreme is defined as; (a) no more than one untreated discharge in ten years from a CSO outfall during the April 1 through October 31 growth period, (b) modeled to not discharge at the 25 year – 24 hour event (during growth period, with normal soil moisture, rainfall distributed to a SCS Type II distribution), or (c) monitored to occur only at rainfalls greater than 4 inches in a 24 hour period. The Department does not intend to require construction of treatment facilities at the following outfalls should they continue to only discharge at the extreme event. This addresses CSO outfalls consistently with SSO outfalls according to the 2002 SSO Policy and 2003 Clarification Statement. The list of untreated CSO outfalls that only discharge at the extreme event is flexible and may be adjusted with the adaptive management CSO correction program.

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
029	Rosa Parks (B27) Rosa Parks & Detroit River	42°19'13" 083°03'56"	Detroit River
030	Vermont (B28) Vermont (extended) & Detroit River	42°19'06" 083°04'09"	Detroit River
037	McKinstry (B35) McKinstry & Detroit River	42°18'19" 083°05'13"	Detroit River
042	Campbell (B40) Campbell & Detroit River	42°18'01" 083°05'30"	Detroit River
048	Pulaski (B59A &B) Pulaski & Rouge River	42°17'21" 083°07'11"	Old Channel Rouge River

6) the outfalls that immediately follow this paragraph are also included in the Limited Discharge Authorization. There are some untreated CSOs that appear to discharge at a minimal frequency and volume. Minimal discharge is defined as actual monitoring of a volume less than 0.3 MG of discharge over a five year period. The Department does not intend to require construction of treatment facilities at the following outfalls should they continue to only discharge at this minimal frequency and volume. The list of untreated CSO outfalls that only discharge at a minimal frequency and volume is flexible and may be adjusted with the adaptive management CSO correction program.

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
024	Griswold (B22) Griswold & Detroit River	42°19'35" 083°02'28"	Detroit River
032	Twenty-First St. (B30) Twenty-First St. & Detroit River	42°18'53" 083°04'31"	Detroit River
034	West Grand Blvd. (B32) West Grand Blvd. & Detroit River	42°18'41" 083°04'50"	Detroit River
035	Swain (B33) Swain & Detroit River	42°18'35" 083°04'56"	Detroit River
036	Scotten (B34) Scotten & Detroit River	42°18'31" 083°05'02"	Detroit River
041	Junction (B39) Junction & Detroit River	42°18'07" 083°05'25"	Detroit River
043	Dragoon (Livernois Relief) (B41) Dragoon (extended) & Detroit River	42°17'49" 083°05'41"	Detroit River
047	Dearborn St. (B45) Dearborn St. & Rouge River	42°17'26" 083°06'59"	Old Channel Rouge River
073	Riverdale (B79) Florence & Rouge River	42°24'36" 083°16'13"	Rouge River

7) the outfalls that immediately follow this paragraph are also included in the Limited Discharge Authorization. These are untreated CSOs that represent the remaining non-core outfalls that will be required to be addressed under the adaptive management CSO correction program. They include the high-priority non-core CSOs. Note that the list of untreated CSO outfalls is flexible and may be adjusted with the adaptive management CSO correction program.

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
005	McClellan (B03) McClellan (extended) & Detroit River	42°21'20" 082°58'02"	Detroit River
006	Fischer (B04) Fischer & Detroit River	42°21'16" 082°59'15"	Detroit River
007	Iroquois (B05) Iroquois & Detroit River	42°21'14" 082°59'21"	Detroit River
008	Helen (B06) Helen & Detroit River	42°20'40" 083°00'06"	Detroit River
009	Mt. Elliott (B07) Mt. Elliott & Detroit River	42°20'24" 083°00'28"	Detroit River
011	Adair (B09) Adair & Detroit River	42°20'16" 083°00'41"	Detroit River
012	Joseph Campau (B10) Joseph Campau & Detroit River	42°10'08" 083°01'02"	Detroit River
016	Orleans Relief (B15) Orleans (Eastside of) & Detroit River	42°19'54" 083°01'36"	Detroit River
017	Orleans (B14) Orleans (Westside of) & Detroit River	42°19'53" 083°01'37"	Detroit River
018	Riopelle (B16) Riopelle & Detroit River	42°19'52" 083°01'42"	Detroit River
019	Rivard (B17) Rivard & Detroit River	42°19'48" 083°01'55"	Detroit River
020	Hastings (B18) Schweizer Place & Detroit River	42°19'46" 083°02'03"	Detroit River
021	Randolph (B19) Randolph & Detroit River	42°19'29" 083°02'26"	Detroit River
022	Bates (B20) Bates & Detroit River	42°19'38" 083°02'32"	Detroit River
023	Woodward (B21) Woodward & Detroit River	42°19'37" 083°02'35"	Detroit River
025	First-Hamilton (B23) First (extended) & Detroit River	42°19'30" 083°02'57"	Detroit River
026	Third St. (B24) Third St. & Detroit River	42°19'28" 083°03'07"	Detroit River

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
027	Cabacier (B25) Brooklyn (extended) & Detroit River	42°19'24" 083°03'26"	Detroit River
028	Eleventh St. (B26) Eleventh St. & Detroit River	42°19'17" 083°03'46"	Detroit River
031	Eighteenth St. (B29) Eighteenth St. & Detroit River	42°18'57" 083°04'31"	Detroit River
033	Twenty-Fourth St. (B31) Twenty-Fourth St. & Detroit River	42°18'47" 083°04'42"	Detroit River
038	Summit-Clark (B36) Summit & Detroit River	42°18'14" 083°05'18"	Detroit River
039	Ferdinand (B37) Ferdinand & Detroit River	42°18'13" 083°05'19"	Detroit River
040	Morrell (B38) Morrell & Detroit River	42°18'10" 083°05'22"	Detroit River
044	Schroeder (B42) Schroeder & West Jefferson	42°17'32" 083°06'00"	Detroit River
046	Cary (B44) Cary & Rouge River	42°17'29" 083°06'47"	Old Channel Rouge River
059	Warren (B54) West Warren & Rouge River	42°20'34" 083°14'57"	Rouge River
060	Tireman (B56, 57 & 58) Tireman & Rouge River	42°20'59" 083°14'51"	Rouge River
061	West Chicago (B60, 61 & 62) West Chicago & Rouge River (East Shore)	42°21'46" 083°14'56"	Rouge River
062	West Chicago (B63) West Chicago & Rouge River (West Shore)	42°21'52" 083°15'18"	Rouge River
063	Plymouth (B64) Plymouth & Rouge River	42°22'18" 083°15'21"	Rouge River
064	Glendale Relief (B65) Rouge Park Golf Course	42°22'33" 083°14'52"	Rouge River
065	Lahser (Dolson) (B67 & 68) Lahser & Rouge River	42°22'52" 083°15'23"	Rouge River
066	Schoolcraft (B70) Jeffries Freeway, I-96 & Rouge River	42°23'07" 083°16'02"	Rouge River

<u>OUTFALL</u>	<u>LOCATION</u>	<u>LAT/LONG</u>	<u>RECEIVING STREAM</u>
067	West Parkway (B69) Jeffries Freeway, I-96 & Rouge River	42°23'07" 083°16'02"	Rouge River
068	Brammel (B71) Ray & Rouge River	42°23'30" 083°15'56"	Rouge River
069	Lyndon (B72) Lyndon & Rouge River	42°23'35" 083°15'57"	Rouge River
072	Puritan (B77) Puritan & Rouge River (East Shore)	42°24'28" 083°16'14"	Rouge River
074	McNichols (B80 & 81) West McNichols & Rouge River	42°24'52" 083°15'59"	Rouge River
075	Glenhurst (B82) Glenhurst & Rouge River	42°25'32" 083°16'19"	Rouge River
077	Seven Mile (B85) West Seven Mile & Rouge River (East Shore)	42°25'44" 083°16'09"	Rouge River
079	Pembroke (B87) Frisbee & East Shore Rouge River	42°26'02" 083°16'24"	Rouge River

Nothing in this section of the permit shall be construed to limit the State of Michigan's ability to pursue remedies under the Michigan Act.

- b. **Qualified Operations and Maintenance Manager for CSO Discharges**
The permittees shall place the wastewater collection system under the supervision of a qualified Operations and Maintenance Manager who shall serve as the contact person for the Department regarding combined sewer discharges. The permittees may replace the manager at any time and shall notify the Department within ten days after the replacement.
- c. **Disconnection of Eaves Troughs and Roof Downspouts**
The permittees shall eliminate direct connections of eaves troughs and roof downspouts to the sewer system throughout the service area tributary to the Upper Rouge CSO outfalls (Outfalls 059-069, 072-075, 077, and 079). This requirement shall be completed for residential property and commercial and industrial properties or as approved by the Department consistent with the permittees' implementation of the Green Storm Water Infrastructure program. In addition, the permittees shall eliminate direct connections of eave troughs and roof downspouts in the service areas tributary to the CSO RTBs, to the CSO Screening & Disinfection Facilities, and to the remaining untreated CSOs based upon the plan detailed in the revised Long-term Control Program. This requirement does not apply if the permittees demonstrates that the disconnection of eaves troughs and roof downspouts is not a cost-effective means of reducing the frequency or duration of combined sewer overflows or of maintaining compliance with this permit. Such a demonstration and supporting documentation shall be submitted to the Department for approval.
- d. **Collection System and CSO Treatment Facilities Operational Plan**
The permittees shall continue implementation of the approved Collection System and CSO Treatment Facilities Operational Plan (Operational Plan). The implementation of the Operational Plan shall be coordinated with the WRRF Wet Weather Operational Plan that is required for development and implementation in accordance with Part I.A.11. of this permit.

On or before April 1 (annually), the permittees shall submit a revised Operational Plan for Department review and approval, which incorporates all changes made to the plan during the last calendar year (items 1-12 below), and supplies the annual discharge documentation (item 13 below). Any changes to the Operational Plan that affect the rate, volume, or characteristics of the discharge, or the system

storage and transportation for conveyance of wet weather flows, shall be submitted to the Department and approved prior to implementation. The operational plan shall define the hydraulic design constraints of the system during both dry and wet weather operation.

The plan shall include:

- 1) the procedures utilized at the permittees' CSO RTBs and Screening & Disinfection Facilities for adjustment of NaOCl disinfectant feed rates to minimize the discharge of total residual chlorine,
- 2) the procedures and schedule for sampling/monitoring the stored NaOCl disinfectant at the permittees' CSO RTBs and Screening & Disinfection Facilities to determine the concentration of available chlorine and assure that the stored NaOCl is of sufficient strength to provide effective disinfection,
- 3) the procedures for sampling/monitoring the available chlorine concentration of each load of NaOCl delivered to the permittees' CSO RTBs and Screening & Disinfection Facilities,
- 4) if applicable, the procedures utilized at the permittees' CSO RTBs and Screening & Disinfection Facilities for adjustment of dehalogenating reagent feed rates to minimize the discharge of excess reagent,
- 5) the procedures to ensure that the collection and treatment systems are operated to maximize treatment,
- 6) the procedures to ensure that all dry weather flows are conveyed to the treatment facilities for treatment without bypass,
- 7) the hydraulic profile and hydraulic operational elevations for system pump stations, regulators, diversion devices, gates, level sensors, interceptors, etc., to ensure the conveyance of all dry weather flows to the treatment facilities for treatment without bypass,
- 8) the procedures to ensure that the sewerage system hydraulic and storage capacity is identified and fully utilized during wet weather events with eventual treatment of stored flows,
- 9) the procedures to ensure that the greatest quantity of wet weather flow is conveyed to the treatment facilities for treatment to minimize untreated wastewater discharges within the region tributary to the GLWA WRRF,
- 10) the hydraulic profile and hydraulic operational elevations for system pump stations, regulators, diversion devices, gates, level sensors, interceptors, etc., to ensure that the greatest quantity of wet weather flow is conveyed to the treatment facilities for treatment to minimize combined sewage discharges,
- 11) the procedures for ongoing inspection of the sewer system within the permittees' jurisdiction for excessive inflow and infiltration and, where necessary, reduction of the excessive infiltration and inflow sources, and the elimination of unauthorized sewer system connections, and
- 12) identification of the location of the rain gauges.
- 13) The permittees shall submit annual reports that supply the documentation of rainfall and the frequency, duration, and volume of all discharge events during the previous 12-month period (from January 1st through December 31st of the previous year).

The permittees shall continue to pursue the coordination of operational plans (Regional Operational Plan) with tributary communities with the intent of maximizing flow conveyance to the GLWA system and minimizing regional CSOs. Once the Regional Operational Plan is approved by the Department, it shall be implemented.

e. New Wastewater Flows

Increased levels of discharge of sanitary sewage from the combined sewer overflow outfalls listed in Part I.A.15.a. of this permit, the CSO RTBs (see Part I.A.6. of this permit), and the CSO Screening and Disinfection Facilities (see Part I.A.7. of this permit) are prohibited unless:

- 1) the increased discharges are the result of new sanitary wastewater flows which, on the basis of sound professional judgment, are within design peak dry weather transportation capacity, or
- 2) the permittees have officially adopted and are timely implementing a definite program, satisfactory to the Department, leading to the construction and operation of necessary collection, transportation, or treatment devices.

f. CSO Control Projects

1) Pertinent CSO Program History

The permittees are continuing to implement CSO Control Programs for the various CSO outfalls that discharge to the Rouge River and the Detroit River. Depending upon the particular CSO Control Program and outfall, the permittees are required to provide for the prohibition, elimination, or adequate treatment of combined sewage discharges containing raw sewage, to comply with the Water Quality Standards at times of discharge.

For the CSO outfalls discharging to the Rouge River, the development and implementation of the CSO Control Programs for the various outfalls was initially established based upon the goals of the Rouge River Remedial Action Plan (RAP), which called for a phased approach to solving the water quality problems of the river. Phase I of the Rouge River RAP extended to 1993 and included 1) monitoring and optimization of the existing combined sewer system, 2) detailed local planning for CSO controls and 3) resolution of financing and institutional problems. Phase II of the Rouge River RAP extended to 2005 (2012 for a few limited outfalls) and called for facility construction based on the goal of protection of public health through the elimination of raw sewage discharges and the control of toxic pollutants. Phase III of the Rouge River RAP follows completion of Phase II facilities and includes further improvements, if necessary, to comply with water quality standards at the time of discharge. Due to the demonstrated financial capability of the permittees for City of Detroit residents in 2009, 2012 and 2017, the CSO Control Program for the CSOs discharging to the Rouge River has been revised as reflected below.

For the CSO outfalls discharging to the Detroit River and the Old Channel of the Rouge River, Department approval of the CSO Control Programs is determined on a case-by-case basis with considerations for environmental impacts, public health impacts, technical feasibility, and economic affordability. As was the case for the Rouge River program, the demonstrated financial capability of the permittees for City of Detroit residents in 2009, 2012 and 2017 also affected the CSO Control Program for the Detroit River and the Old Channel of the Rouge River, and has been revised as reflected below.

In addition, the CSO Control Program now includes significant Green Storm water Infrastructure (GSI) requirements that are an important component of the approved Long-Term CSO Control Program.

Previous Long-Term CSO Control Program Documents include:

- Original Long-Term CSO Control Plan (1996)
- Long-Term CSO Control Plan Update (2002)
- Amendment Rouge (2008)
- Amendment Detroit (2008)
- Evaluation of CSO Control Alternative (for the Upper Rouge Outfalls) (December 15, 2009)

- Supplemental Report on Alternative CSO Controls for the Upper Rouge Outfalls) (April 30, 2010)

The implementation and completion of the CSO Control Program indicated in Part I.A.15.f. and g. are a necessary and essential requirement of this permit.

2) CSO Correction Program Moving Forward

The permittees shall control remaining combined sewer discharges, that are not classified as either extreme or minimal (see Part 1.A.15.a.5) & 6)), to eliminate the discharges or provide adequate treatment of the combined sewage discharges to comply with Water Quality Standards at times of discharge. Upon completion of the RRO disinfection project at the GLWA WRRF and commencing final use of Outfall 050A, the permittees will have completed core elements of their CSO control program and will have achieved a very high level of CSO control. It has been determined that this core level of control has routinely achieved adequate treatment of 95% of the annual combined sewer volume to the collection system. While additional CSO control measures are needed to fully comply with Michigan's Water Quality Standards, as the permittees moves into the final phases of the CSO control program it is appropriate to plan and schedule the remaining control measures, taking into account what has been put in place to date and lessons learned, the unique technical and financial situation of the city of Detroit, and the nature of the remaining CSO challenges.

Based on the foregoing, the permittees shall proceed with remaining CSO corrections using an adaptive management approach. This means that as new information is gained from: (1) evaluation of existing CSO projects and new treatment technologies, (2) evaluation of real-time collection system controls, (3) more accurate and complete data on CSO discharge frequency and volume, (4) benefits of less flow to the collection system from green storm water infrastructure (GSI), (5) benefits of less flow to the collection system due to the City's drainage charge program and new storm water ordinance, (6) benefits of less flow to the collection system as the City continues its sewer rehabilitation program, and (7) any other pertinent information, future CSO controls can be adapted to best provide cost-effective elimination of discharges, adequate treatment of discharges, or classification of discharges as minimal or extreme. Note that for purposes of designing CSO correction projects, minimal discharge is defined as less than 0.3 MG of discharge over a five year period, and extreme is defined as; (a) no more than one untreated discharge in ten years from a CSO outfall during the April 1 through October 31 growth period, (b) modeled to not discharge at the 25 year – 24 hour event (during growth period, with normal soil moisture, rainfall distributed to a SCS Type II distribution), or (c) monitored to occur only at rainfalls greater than 4 inches in a 24 hour period. The performance standard can be based on actual monitoring data normalized for a typical and representative 10-year period of rainfall record or predictively determined based on a calibrated and verified continuous model using a typical and representative 10-year period of rainfall record or other method as determined acceptable by the Department.

The permittees shall propose the non-core CSO correction projects to be designed, constructed, and operated to provide CSO elimination or adequate treatment during the subsequent five-year permit cycle, with each permit reapplication beginning in April 2022. High priority non-core outfalls should generally be addressed first, and outfalls thought of as high priority can change at any time due to implementation of the adaptive management approach. City of Detroit residents within the DWSD service area are "high burden" status based on sewer fees paid as a percentage of median annual household income. Planning of CSO control measures may reflect the permittees' financial capacity for City of Detroit residents determined in the Financial Capability Evaluation that is submitted with each permit reapplication. Based on current and projected CSO capital revenue requirements, and the current average cost per Detroit household for wastewater treatment and CSO control as a percentage of Detroit median household income, the Department does not expect the permittees to propose non-core CSO correction projects with this permit. The permittees shall next propose non-core CSO correction projects for review and approval with the permit reapplication required by April 4, 2022 (and then on April 4, 2027, and April 4, 2032). However, this first tier of non-core projects during 2023 through 2027 is expected to be relatively low cost. Discussion between the permittees and the Department have determined that low cost projects can include connection of CSO discharges to existing CSO treatment facilities, limited storage projects based on the performance standard with no disinfection, outfall gates and in-system storage projects, increased regulator flow capacity, separation projects that use smaller sanitary pipes in existing larger combined sewers to carry sanitary sewage to

GLWA interceptors while the existing combined sewer becomes a storm sewer, and others. At each application submittal in 2022, 2027, and 2032, the project proposal shall include an updated Financial Capability Evaluation that may also include other financial factors as appropriate. Reissued permits will then be drafted and issued with schedules for approved CSO correction projects that provide continuing progress toward meeting water quality standards. The permittees shall prepare an evaluation of Financial Capability, consistent with state and federal guidance, and shall submit the evaluation with the applications for reissuance of this permit (see the cover page of this permit for the next application due date). The Financial Capability Report shall be in the form of previous reports utilizing the EPA Financial Capability Guidance Document (USEPA 832-B-97-004; February, 1997), and updated with information as may be available in order to assess the permittees' ability to undertake future capital improvement projects related to the Long-Term CSO Control Program. This permit may be modified in accordance with applicable law and rules to incorporate revisions to conform to pertinent laws or rules, or as necessary to address prevailing situations.

Based on information currently available, the following are lists by water body that are high priority CSOs that require control. These outfalls can be revised at any time by the permittees or the Department, reflecting adaptive management considerations. While either the permittees or Department can propose changes at any time, an agreement between the two parties is required and shall be made in writing. The goal will be to complete projects fully addressing all high priority outfalls before October 1, 2037.

Rouge River non-core CSOs (these can be changed by mutual agreement between the permittees and the Department)

High Priority Outfalls
059, 061, 064, 065, 074

Detroit River non-core CSOs (these can be changed by mutual agreement between the permittees and the Department)

High Priority Outfalls
005, 007, 009, 012, 022, 025, 031, 038

3) Adaptive Management Program for this Permit

The adaptive management approach for this permit, before beginning relatively low cost CSO correction projects from 2023-2027, looks at the (1) evaluation of existing CSO projects and new treatment technologies, (2) evaluation of real-time collection system controls, (3) more accurate and complete data on CSO discharge frequency and volume, (4) benefits of less flow to the collection system from green storm water infrastructure (GSI), (5) benefits of less flow to the collection system due to the City's drainage charge program and new storm water ordinance, (6) benefits of less flow to the collection system as the City continues its sewer rehabilitation program, and (7) any other pertinent information. The permittees shall use the above measures, as appropriate, to further reduce untreated CSO discharges on an ongoing basis from the collection system before starting CSO projects from 2023 - 2037.

On or before April 1st (annually starting in 2020), the permittees shall prepare a joint Progress Report that summarizes; 1) significant real time controls that occurred during the preceding calendar year, 2) GSI implementation work during the preceding year that has been undertaken and completed, including a work plan for GSI implementation projects for the next year, documentation of the annual expenditure for the preceding year, and documentation of a cumulative total-spent-to-date on the GSI program, 3) benefits from the new storm water ordinance and green credit program, and 4) benefits from the City sewer rehabilitation program. The report shall summarize the total benefits from all programs by including; a) an updated estimate of the annual volume of wet weather flow that has been removed from the combined sewer system, b) the resulting frequency, volume and duration of CSO discharges (based on actual monitoring), and c) the predicted change modeled continuously and at design events to frequency, volume and duration of CSO discharges based on the calibrated hydraulic model developed in the Master Plan effort. The report shall reference the CSO discharge report submitted under Part I.A.15.d.(13) of this permit and include the pertinent data as a reference. As part of this reporting process, it shall be documented that an average of \$3 million dollars per fiscal year was spent for 2018

and 2019, and \$2 million dollars per year for 2020, 2021, and 2022 for the GSI program (these expenditures are an enforceable requirement of this permit).

A more complete description of the adaptive management approach includes:

a) Real-time Control

The GLWA is in the process of determining if real-time control can be used to help further minimize or even eliminate some untreated CSO discharges. One real-time control discussion currently taking place is the Interim Wet Weather Operations Plan (IWOP). The operational changes agreed to between the permittees and the Department in the IWOP will be reported in the Operational Plan Annual Update (Part 1.A.15 d.). The IWOP is evaluating if critical system regulators, gates, pumps, etc., can be adjusted to allow for more treated CSO, and less untreated CSO from the remaining CSO outfalls. Approved adjustments will be at least acceptable until completion of all non-core CSO correction projects and shall be included in Operational Plan Annual Updates. The evaluation shall include all necessary supporting documentation, including hydraulic model runs if appropriate.

b) Green Storm Water Infrastructure (GSI)

For the west side of the City, there is a GSI program in the tributary area to Rouge River Outfalls 059-069, 072-075, 077, and 079. DWSD has developed and is implementing a Department approved GSI Plan for this area consistent with the "Evaluation of CSO Control Alternatives" report dated December 15, 2009. The GSI Plan describes a process for locating, designing, constructing, operating, and evaluating GSI in these sewersheds. GSI implementation shall be planned to capture, reduce, or otherwise control wet weather flows that would otherwise flow into the sewer system and contribute to CSOs, at the permittees' direction. The Plan includes the following elements:

- (1) Provisions for disconnection of residential downspouts and disconnection of commercial and industrial downspouts where feasible (see Part I.A.15.c.).
- (2) Provisions for demolition and removal of vacant structures and replacement with pervious land cover. Where demolition is planned and implemented at sites that will be re-purposed for GSI, the demolition specifications shall ensure that basements and other impervious surfaces at the sites are removed, that the site is raked to remove large rocks and construction debris, and that engineered soils consisting of an appropriate mix of topsoil, compost, and sand is applied following the demolition to support plant growth and promote infiltration.
- (3) Provisions for installation of bioswales along roadways and parking lots to intercept runoff and reduce storm water inputs to the combined sewer system from impervious surfaces.
- (4) Provisions for installation of GSI and/or BMPs at commercial and residential properties to capture and retard storm water runoff.
- (5) Provisions for tree planting for uptake and evapotranspiration along roadways and open spaces.
- (6) Provisions for other GSI implementation projects as determined to be appropriate.
- (8) Processes for public outreach and public participation in selecting sites and implementing GSI practices.
- (9) Procedures/methods for tracking GSI implementation and measuring effects.
- (10) Provisions for ensuring appropriate maintenance of sites where GSI has been implemented, including roles and schedules for maintenance.
- (11) Provisions for ensuring storm water management (runoff reduction) benefits associated with GSI implementation continue over time, even as redevelopment may occur in the sewersheds.

The permittees shall continue to implement GSI in these sewersheds. The investment in GSI in these sewersheds shall be an average of 3 million dollars per fiscal year for the ten-year period ending 2019

(for a total of \$30 million), and an average of 2 million dollars per year for the following 10 years (for a total of \$20 million). GSI implementation will be in accordance with the GSI Plan.

For the near-east side of the City, there has been another GSI program in the tributary area to Detroit River Outfalls 005 - 009, 011, and 012. Because of the potential for some larger-scale green projects due to a relatively large amount of vacant land in the area, it may be possible to eliminate or reduce the size of some previously envisioned CSO treatment facilities for this area using the combination of GSI implementation along with possible sewer separation, and other engineering solutions. With GSI implementation now spreading across the city, it is acceptable for the city to use one-third (1/3) of the total GSI expenditures on projects upstream of untreated CSOs other than Rouge River Outfalls 059-069, 072-075, 077, and 079.

c) Storm Water Control

1) On or before April 1, 2018, (submitted) the permittees shall submit to the Department for review and approval a storm water control requirement for areas of new development and/or redevelopment. This storm water control requirement is primarily a focus within the Rouge Sewer District and Central Sewer District, as it is these two Districts that have untreated CSOs. Therefore, the permittees shall propose a level of storm water control for new development and redevelopment in these two sewer districts, and for the circumstances stated above, that is designed to help further reduce the volume and frequency of untreated CSO discharges, and a procedure and schedule for implementing this control requirement.

2) Storm water runoff from new development and redevelopment that will be conveyed through storm sewers to DWSD's combined sewers will require control to help further reduce volume and frequency of untreated CSO discharges. These are projects that will require construction plan review by the permittees, and a Part 41 construction permit issued by the Department. Please note that in most cases, new combined sewers will no longer be permitted under Part 41 (except for combined sewer relocation projects). Note that this is not a requirement for storm sewers subject to Permit No. MIS040000 issued to the City of Detroit, as the storm sewers under MIS040000 discharge directly to surface waters and are not owned by the DWSD.

d) City Sewer Rehabilitation

DWSD is currently working on a more robust annual program to remove infiltration/inflow (I/I) from its combined collection system. It is the Department's understanding that this program has a budget of about \$20 million per year.

g. Combined Sewer Overflow Control Program Schedule

1) West-side Model; Rouge River Outfalls 059-069, Outfalls 072-075, Outfall 077, and Outfall 079. For untreated combined sewer overflows from Outfalls 059-069, Outfalls 072-075, Outfall 077, and Outfall 079, the permittees shall determine the accurate frequency and volume of untreated CSO discharges and amend the "Supplemental Report on Alternative CSO Controls for the Upper Rouge River," dated April 30, 2010 according to the following schedule:

- a) The work plan has been approved by the Department that (1) sets forth the monitoring of the 17 CSOs that will be accomplished to accurately determine the frequency and volume of these untreated CSO discharges, (2) uses this monitoring along with the current Ovation monitoring as appropriate in a calibrated and verified model to accurately detail the volume and frequency of the 17 CSOs during a representative and typical 10-year period of rainfall record, and (3) to determine the peak hour flow at the 10 yr – 1 hr event of each of the 17 CSOs. The permittees shall continue to implement the approved work plan.
- b) On or before April 15, 2019, (submitted) the permittees shall submit a report to the Department for review and approval that summarizes the determination and provides the volume and frequency of these 17 CSOs over a representative and typical 10-year period of rainfall record and provides the peak hour flow at the 10 yr – 1 hr event for each of these 17 CSOs;

- c) On or before November 15, 2022, the permittees shall submit an amendment for Department review and approval to the "Supplemental Report on Alternative CSO Controls for the Upper Rouge River" (dated April 30, 2010) that describes any changes to the recommended long-term CSO control projects for the 17 CSOs. This plan may propose an alternative to the use of 10 minutes of detention at the 10 year – 1 hour event, at the permittees' discretion;
- 2) Near eastside; Detroit River Outfalls 005-009, 011, and 012. The permittees shall develop a revised CSO Control Plan for this tributary area in accordance with the following schedule:
- On or before November 15, 2022, the permittees shall submit to the Department for review and approval an update to their Long-term CSO Control program (Detroit update 2008) for providing elimination or adequate treatment of CSO Outfalls 005-009, Outfall 011, and Outfall 012 to meet water quality standards at times of discharge. This plan shall consider the GI recommendations and potential for storm water reduction from the completed 205(j) report for this area. This plan may propose an alternative control requirement for the Long-term CSO control program.
- 3) The permittees may choose to offer an entire updated Long-term CSO Control program for all Detroit River CSOs. This updated plan can include a totally revised Detroit update (2008) for all remaining CSOs. Note that CSOs can be prohibited, eliminated, or adequately treated to meet water quality standards at times of discharge. If the permittees decide to pursue this approach, then the revised plan is due on or before November 15, 2022, for Department review and approval.

Following implementation of any phase of any of the approved Control Programs contained in Part I.A.15.f. and g. of this permit, the Control Program(s) may be reevaluated by the permittees or the Department. Future permits may include requirements to conduct water quality evaluations designed to verify that the overall CSO control program is providing adequate treatment to meet water quality standards. This permit may be modified in accordance with applicable laws and rules, to incorporate revisions necessary to conform to pertinent rules or laws, or as necessary to address prevailing situations, such as technical or financial constraints.

h. Notification and Testing Requirements

The federal rule promulgated by the United States Environmental Protection Agency in 40 CFR Part 122 establishing the public notification requirements for CSO discharges to the Great Lakes basin took effect February 7, 2018.

On or before August 7, 2018, (submitted) the permittees shall submit to the Department for approval, a public notification plan in accordance with 40 CFR 122.38(c). Additionally, on or before April 4, 2022, with the application for reissuance, the permittees shall submit to the Department for approval, an updated public notification plan.

Beginning November 7, 2018, all permittees authorized to discharge untreated or treated CSO to the Great Lakes Basin must provide public notification of CSO discharges in accordance with 40 CFR 122.38(a) and the approved public notification plan. The requirements include but are not limited to the following: notification of the local public health department, other potentially affected public entities and the public; and signage, where feasible at discharge points and other potentially impacted public access areas. In addition, in accordance with Section 324.3112a of the NREPA, the permittees shall provide notification to a newspaper of general circulation in the county in which the discharge occurred or is occurring. To the extent that a conflict may arise between Part I.A.15.h. and Part I.A.16., the Department approved Public Notification Plan shall govern.

16. Untreated or Partially Treated Sewage Discharge Reporting and Testing Requirements

In accordance with Section 324.3112a of the NREPA, if untreated or partially treated sewage is directly or indirectly discharged from a sewer system onto land or into the waters of the state, the entity responsible for the sewer system shall immediately, but not more than 24 hours after the discharge begins, notify, by telephone, the Department, local health departments, a daily newspaper of general circulation in the county in which the permittees are located, and a daily newspaper of general circulation in the county or counties in which the municipalities whose waters may be affected by the discharge are located that the discharge is occurring.

The permittees shall also annually contact municipalities, including the superintendent of a public drinking water supply with potentially affected intakes, whose waters may be affected by the permittees' discharge of untreated or partially treated sewage, and, if those municipalities wish to be notified in the same manner as specified above, the permittees shall provide such notification. Such notification shall also include a daily newspaper in the county of the affected municipality.

At the conclusion of the discharge, written notification shall be submitted in accordance with and on the "Report of Discharge Form" available via the internet at: <http://www.deq.state.mi.us/csosso/>, or, alternatively for combined sewer overflow discharges, in accordance with notification procedures approved by the Department.

In addition, in accordance with Section 324.3112a of the NREPA, each time a discharge of untreated or partially treated sewage occurs, the permittees shall test the affected waters for *Escherichia coli* to assess the risk to the public health as a result of the discharge and shall provide the test results to the affected local county health departments and to the Department. The testing shall be done at locations specified by each affected local county health department but shall not exceed ten (10) tests for each separate discharge event. The affected local county health department may waive this testing requirement, if it determines that such testing is not needed to assess the risk to the public health as a result of the discharge event. The results of this testing shall be submitted with the written notification required above, or, if the results are not yet available, submitted as soon as they become available. This testing is not required, if the testing has been waived by the local health department, or if the discharge(s) did not affect surface waters.

Permittees accepting sanitary or municipal sewage from other sewage collection systems are encouraged to notify the owners of those systems of the above reporting and testing requirements.

17. Pollutant Minimization and Source Evaluation Program for Perfluorooctane Sulfonate (PFOS) and/or Perfluorooctanoic Acid (PFOA)

The goal of the Pollutant Minimization and Source Evaluation Program is to identify and address sources of perfluorooctane sulfonate (PFOS) and/or perfluorooctanoic acid (PFOA) and to reduce and maintain the effluent concentrations of PFOS and/or PFOA at or below the water quality standards (WQS) and/or the Water Quality-Based Effluent limit (WQBEL). The WQS is 11 ng/L for PFOS and the WQBEL for PFOA is 8.04 ug/l.

On or before October 1, 2019, the permittee shall submit an approvable Pollutant Minimization and Source Evaluation Program for PFOS and/or PFOA to proceed toward the goal. The Pollutant Minimization and Source Evaluation Program shall continue work under the IPP Interim Initiative and shall include the following at a minimum:

- a. Identification of and strategies to identify any additional potential and probable PFOS and/or PFOA sources
- b. Monitoring plan for the permitted facility's influent and effluent and effluent from potential sources
- c. Implemented measures thus far to eliminate, reduce, and/or control sources, and an assessment of the degree of success and the strategies used to measure success
- d. Proposed measures and implementation schedules for elimination, control, and/or reduction of the identified sources (prioritizing highest loadings and concentrations), and the strategies that will be used to measure success

The Pollutant Minimization and Source Evaluation Program shall be implemented upon approval by the Department.

On or before May 1 of each year following Pollutant Minimization and Source Evaluation Program implementation, the permittee shall submit to the Department a status report for the previous calendar year. Upon written notification by the Department, the permittee may be required to submit more frequent status reports. Status reports at a minimum shall include:

- a. Complete listing of PFOS and/or PFOA sources
- b. Summary of influent and effluent monitoring data
- c. Summary of monitoring data from known or potential sources
- d. History and compliance status for sources
- e. Implemented measures to eliminate, reduce, or control sources, (prioritizing highest loadings and concentrations), and an assessment of the degree of success and the strategies used to measure success
- f. Proposed measures and schedules for elimination, control, or reduction of any newly identified PFOS and/or PFOA sources (prioritizing highest loadings and concentrations), and the strategies that will be used to measure success
- g. Barriers to implementation and revisions to the implementation schedule
- h. Laboratory reports, if not previously supplied

Any information generated as a result of the Pollutant Minimization and Source Evaluation Program set forth in this permit may be used to support a request to modify the Pollutant Minimization and Source Evaluation Program or to demonstrate that the requirement has been completed satisfactorily.

A request for modification of the approved Pollutant Minimization and Source Evaluation Program shall be submitted in writing to the Department along with supporting documentation for review and approval. The Department may approve modifications to the approved Pollutant Minimization and Source Evaluation Program, including a reduction in the frequency of the influent and known or potential source monitoring requirements. Approval of a Pollutant Minimization and Source Evaluation Program modification does not require a permit modification.

This permit may be modified in accordance with applicable laws and rules to include additional PFOS and/or PFOA conditions and/or limitations as necessary.

18. Collection System Contingency Plan

An emergency condition at the WRRF might occur that requires reduced (or even no) influent flows to the WRRF. Under Rule 299.2959 of Part 41, the permittee is required to minimize discharge of excessive pollutants. On or before July 1, 2020, the permittee shall submit to the Department for review and approval, a report that documents how the collection system and WRRF would be operated if an emergency condition required reduced influent flow (or no flow) to the WRRF to minimize discharge of excessive pollutants per Rule 299.2959 of Part 41 of PA 451. This could involve in-system storage of flows, use of Retention Treatment Basins for storage and potentially treated discharge, rerouting of flow, use of portions of the WRRF as appropriate, etc. The report shall evaluate operation of the collection system and WRRF, considering at least two hypothetical conditions with no influent flow to the WRRF; a duration of six (6) hours of no influent flow, and a duration of 24 hours of no influent flow.

19. Facility Contact

The "Facility Contact" was specified in the application. The permittees may replace the facility contact at any time, and shall notify the Department in writing within 10 days after replacement (including the name, address and telephone number of the new facility contact).

- a. The facility contact shall be (or a duly authorized representative of this person):
 - for a corporation, a principal executive officer of at least the level of vice president; or a designated representative if the representative is responsible for the overall operation of the facility from which the discharge originates, as described in the permit application or other NPDES form,
 - for a partnership, a general partner,
 - for a sole proprietorship, the proprietor, or
 - for a municipal, state, or other public facility, either a principal executive officer, the mayor, village president, city or village manager or other duly authorized employee.
- b. A person is a duly authorized representative only if:
 - the authorization is made in writing to the Department by a person described in paragraph a. of this section; and
 - the authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the facility (a duly authorized representative may thus be either a named individual or any individual occupying a named position).

Nothing in this section obviates the permittees from properly submitting reports and forms as required by law.

20. Monthly Operating Reports

Part 41 of Act 451 of 1994 as amended, specifically Section 324.4106 and associated R 299.2953, requires that the permittees file with the Department, on forms prescribed by the Department, operating reports showing the effectiveness of the treatment facility operation and the quantity and quality of liquid wastes discharged into waters of the state.

Within thirty (30) days of the effective date of this permit, the permittees shall submit to the Department a revised treatment facility monitoring program to address monitoring requirement changes reflected in this permit, or submit justification explaining why monitoring requirement changes reflected in this permit do not necessitate revisions to the treatment facility monitoring program. The permittees shall implement the revised treatment facility monitoring program upon approval from the Department. Applicable forms and guidance are available on the Department's web site at http://www.michigan.gov/deq/0,1607,7-135-3313_44117---,00.html. The permittees may use alternate forms if they are consistent with the approved treatment facility monitoring program. Unless the Department provides written notification to the permittees that monthly submittal of operating reports is required, operating reports that result from implementation of the approved treatment facility monitoring program shall be maintained on site for a minimum of three (3) years and shall be made available to the Department for review upon request.

21. Discharge Monitoring Report – Quality Assurance Study Program

The permittees shall participate in the Discharge Monitoring Report – Quality Assurance (DMR-QA) Study Program. The purpose of the DMR-QA Study Program is to annually evaluate the proficiency of all in-house and/or contract laboratory(ies) that perform, on behalf of the facility authorized to discharge under this permit, the analytical testing required under this permit. In accordance with Section 308 of the Clean Water Act (33 U.S.C. § 1318); and R 323.2138 and R 323.2154 of Part 21, Wastewater Discharge Permits, promulgated under Part 31 of the NREPA, participation in the DMR-QA Study Program is required for all major facilities, and for minor facilities selected for participation by the Department.

Annually and in accordance with DMR-QA Study Program requirements and submittal due dates, the permittees shall submit to the Michigan DMR-QA Study Program state coordinator all documentation required by the DMR-QA Study. DMR-QA Study Program participation is required only for the analytes required under this permit and only when those analytes are also identified in the DMR-QA Study.

If the permitted facility's status as a major facility should change, participation in the DMR-QA Study Program may be reevaluated. Questions concerning participation in the DMR-QA Study Program should be directed to the Michigan DMR-QA Study Program state coordinator.

All forms and instructions required for participation in the DMR-QA Study Program, including submittal due dates and state coordinator contact information, can be found at <http://www.epa.gov/compliance/discharge-monitoring-report-quality-assurance-study-program>.

Section B. Storm Water Pollution Prevention

This section is not required.

PART I**Section C. Industrial Waste Pretreatment Program****1. Federal Industrial Pretreatment Program**

- a. The permittees shall implement the Federal Industrial Pretreatment Program approved on June 26, 1997, and any subsequent modifications approved up to the issuance of this permit. Approval of substantial program modifications after the issuance of this permit shall be incorporated into this permit by minor modification in accordance with 40 CFR 122.63.
- b. The permittees shall comply with R 323.2301 through R 323.2317 of the Michigan Administrative Code (Part 23 Rules), the General Pretreatment Regulations for Existing and New Sources of Pollution (40 CFR Part 403), and the approved Federal Industrial Pretreatment Program.
- c. The permittees shall have the legal authority and necessary interjurisdictional agreements that provide the basis for the implementation and enforcement of the approved Federal Industrial Pretreatment Program throughout the service area. The legal authority and necessary interjurisdictional agreements shall include, at a minimum, the authority to carry out the activities specified in R 323.2306(a).
- d. The permittees shall develop procedures which describe, in sufficient detail, program commitments which enable implementation of the approved Federal Industrial Pretreatment Program, 40 CFR Part 403, and the Part 23 Rules in accordance with R 323.2306(c).
- e. The permittees shall establish an interjurisdictional agreement (or comparable document) with all tributary governmental jurisdictions. Each interjurisdictional agreement shall contain, at a minimum, the following:
 - 1) identification of the agency responsible for the implementation and enforcement of the approved Federal Industrial Pretreatment Program within the tributary governmental jurisdiction's boundaries; and
 - 2) the provision of the legal authority which provides the basis for the implementation and enforcement of the approved Federal Industrial Pretreatment Program within the tributary governmental jurisdiction's boundaries.
- f. The permittees shall prohibit discharges that:
 - 1) cause, in whole or in part, the permittees, failure to comply with any condition of this permit or the NREPA;
 - 2) restrict, in whole or in part, the permittee's management of biosolids;
 - 3) cause, in whole or in part, operational problems at the treatment facility or in its collection system;
 - 4) violate any of the general or specific prohibitions identified in R 323.2303(1) and (2);
 - 5) violate categorical standards identified in R 323.2311; and
 - 6) violate local limits established in accordance with R 323.2303(4).
- g. The permittees shall maintain a list of its nondomestic users that meet the criteria of a significant industrial user as identified in R 323.2302(cc).
- h. The permittees shall develop an enforcement response plan which describes, in sufficient detail, program commitments which will enable the enforcement of the approved Federal Industrial Pretreatment Program, 40 CFR Part 403, and the Part 23 Rules in accordance with R 323.2306(g).

- i. The Department may require modifications to the approved Federal Industrial Pretreatment Program which are necessary to ensure compliance with 40 CFR Part 403 and the Part 23 Rules in accordance with R 323.2309.
- j. The permittees shall not implement changes or modifications to the approved Federal Industrial Pretreatment Program without notification to the Department. Any substantial modification shall be subject to Department public noticing and approval in accordance with R 323.2309.
- k. The permittees shall maintain an adequate revenue structure and staffing level for effective implementation of the approved Federal Industrial Pretreatment Program.
- l. The permittees shall develop and maintain, for a minimum of three (3) years, all records and information necessary to determine nondomestic user compliance with 40 CFR Part 403, Part 23 Rules and the approved Federal Industrial Pretreatment Program. This period of retention shall be extended during the course of any unresolved enforcement action or litigation regarding a nondomestic user or when requested by the Department or the United States Environmental Protection Agency. All of the aforementioned records and information shall be made available upon request for inspection and copying by the Department and the United States Environmental Protection Agency.
- m. The permittees shall evaluate the approved Federal Industrial Pretreatment Program for compliance with the 40 CFR Part 403, Part 23 Rules and the prohibitions stated in item f. (above). Based upon this evaluation, the permittees shall propose to the Department all necessary changes or modifications to the approved Federal Industrial Pretreatment Program no later than the next Industrial Pretreatment Program Annual Report due date (see item o. below).
- n. The permittees shall develop and enforce local limits to implement the prohibitions listed in item f above. Local limits shall be based upon data representative of actual conditions demonstrated in a maximum allowable headworks loading analysis. An evaluation of whether the existing local limits need to be revised shall be submitted to the Department by June 1, 2021. The submittal shall provide a technical evaluation of the basis upon which this determination was made which includes information regarding the maximum allowable headworks loading, collection system protection criteria, and worker health and safety, based upon data collected since the last local limits review.

The following pollutants shall be evaluated:

- 1) Arsenic, Cadmium, Chromium, Copper, Cyanide, Lead, Mercury, Nickel, Silver, and Zinc;
 - 2) Pollutants that are subject to limits or monitoring in this permit;
 - 3) Pollutants that have an existing local limit; and,
 - 4) Other pollutants of concern which would reasonably be expected to be discharged or transported by truck or rail or otherwise introduced into the POTW.
- o. On or before April 1 of each year, the permittees shall submit to the Department, as required by R 323.2310(8), an Industrial Pretreatment Program Annual Report on the status of program implementation and enforcement activities. The reporting period shall begin on January 1 and end on December 31. At a minimum, the Industrial Pretreatment Program Annual Report shall include:
- 1) the Pretreatment Program Report data identified in Appendix A to 40 CFR part 127 – NPDES Electronic Reporting;
 - 2) a summary of changes to the approved IPP that have not been previously reported to the Department;

- 3) a summary of results of all the sampling and analyses performed of the WRRF's influent, effluent, and biosolids conducted in accordance with approved methods during the reporting period. The summary shall include the monthly average, daily maximum, quantification level, and number of samples analyzed for each pollutant. At a minimum, the results of analyses for all locally limited parameters for at least one monitoring event that tests influent, effluent and biosolids during the reporting period shall be submitted with each report, unless otherwise required by the Department. Sample collection shall be at intervals sufficient to provide pollutant removal rates, unless the pollutant is not measurable; and;
 - 4) any other relevant information requested by the Department.
- p. The permittee is required under this permit and R 323.2303(4) of the Michigan Administrative Code to review and update their local limits when:
- 1) New pollutants are introduced.
 - 2) New pollutants that were previously unevaluated are identified
 - 3) New water quality or biosolids standards are established or additional information becomes available about the nature of pollutants, such as removal rates and accumulation in biosolids. Substantial increases of pollutants are proposed as required in the notification of new or increased uses in accordance with the provisions of 40 CFR 122.42.

2. Schedule for Notification to Contributing Jurisdictions

On or before May 1st and November 1st of each year, the permittees shall submit to the Department a report demonstrating the efforts and progress toward achieving the requirement of having all contributing jurisdictions adopt a legal authority that is equivalent to or more restrictive than the permittees', including the revised local limits to be incorporated by the permittees as result of the requirements of Part I.C.2. of this permit. This legal authority includes the provisions of Ordinance 08-05 (Detroit City Code Chapter 56, Article III. Division 3) and subsequent revisions to the local limits. These progress reports shall be submitted every six months until the requirement is achieved. The biannual progress reports shall contain:

- a. a listing of all contributing jurisdictions,
- b. the status of each contributing jurisdiction's adoption of adequate legal authority, and
- c. for contributing jurisdictions who have not yet adopted adequate legal authority, a description of the steps/actions the permittees have taken to assure progress toward the contributing jurisdiction's adoption of adequate legal authority.

The permittees shall, to the best of its ability, work with those contributing jurisdictions who did not adopt adequate legal authority by January 1, 2008, to obtain such legal authority.

PART I**Section D. Residuals Management Program****1. Residuals Management Program for Land Application of Biosolids**

The permittees are authorized to land-apply bulk biosolids or prepare bulk biosolids for land application in accordance with the permittees' approved Residuals Management Program (RMP) approved on April 22, 2008, and approved modifications thereto, in accordance with the requirements established in R 323.2401 through R 323.2418 of the Michigan Administrative Code (Part 24 Rules). The approved RMP, and any approved modifications thereto, are enforceable requirements of this permit. Incineration, landfilling and other residual disposal activities shall be conducted in accordance with Part II.D.7. of this permit. The Part 24 Rules can be obtained via the internet (<http://www.michigan.gov/deq/> and on the left side of the screen click on Water, Biosolids & Industrial Pretreatment, Biosolids then click on Biosolids Laws and Rules Information which is under the Laws & Rules banner in the center of the screen).

a. Annual Report

On or before October 30 of each year, the permittees shall submit an annual report to the Department for the previous fiscal year of October 1 through September 30. The report shall be submitted electronically via the Department's MiWaters system at <https://miwaters.deq.state.mi.us>. At a minimum, the report shall contain:

- 1) a certification that current residuals management practices are in accordance with the approved RMP, or a proposal for modification to the approved RMP; and
- 2) a completed Biosolids Annual Report Form, available at <https://miwaters.deq.state.mi.us>.

b. Modifications to the Approved RMP

Prior to implementation of modifications to the RMP, the permittees shall submit proposed modifications to the Department for approval. The approved modification shall become effective upon the date of approval. Upon written notification, the Department may impose additional requirements and/or limitations to the approved RMP as necessary to protect public health and the environment from any adverse effect of a pollutant in the biosolids.

c. Record Keeping

Records required by the Part 24 Rules shall be kept for a minimum of five years. However, the records documenting cumulative loading for sites subject to cumulative pollutant loading rates shall be kept as long as the site receives biosolids.

d. Contact Information

RMP related submittals to the Department shall be to the Southeast Michigan District Supervisor of the Water Resources Division. The Southeast Michigan District Office is located at 27700 Donald Court, Warren Michigan, 48092-2793, Telephone: 586-753-3750, Fax: 586-753-3751.

PART II

Part II may include terms and /or conditions not applicable to discharges covered under this permit.

Section A. Definitions

Acute toxic unit (TU_A) means $100/LC_{50}$ where the LC_{50} is determined from a whole effluent toxicity (WET) test which produces a result that is statistically or graphically estimated to be lethal to 50% of the test organisms.

Annual monitoring frequency refers to a calendar year beginning on January 1 and ending on December 31. When required by this permit, an analytical result, reading, value or observation shall be reported for that period if a discharge occurs during that period.

Authorized public agency means a state, local, or county agency that is designated pursuant to the provisions of section 9110 of Part 91 of the NREPA to implement soil erosion and sedimentation control requirements with regard to construction activities undertaken by that agency.

Best management practices (BMPs) means structural devices or nonstructural practices that are designed to prevent pollutants from entering into storm water, to direct the flow of storm water, or to treat polluted storm water.

Bioaccumulative chemical of concern (BCC) means a chemical which, upon entering the surface waters, by itself or as its toxic transformation product, accumulates in aquatic organisms by a human health bioaccumulation factor of more than 1000 after considering metabolism and other physiochemical properties that might enhance or inhibit bioaccumulation. The human health bioaccumulation factor shall be derived according to R 323.1057(5). Chemicals with half-lives of less than 8 weeks in the water column, sediment, and biota are not BCCs. The minimum bioaccumulation concentration factor (BAF) information needed to define an organic chemical as a BCC is either a field-measured BAF or a BAF derived using the biota-sediment accumulation factor (BSAF) methodology. The minimum BAF information needed to define an inorganic chemical as a BCC, including an organometal, is either a field-measured BAF or a laboratory-measured bioconcentration factor (BCF). The BCCs to which these rules apply are identified in Table 5 of R 323.1057 of the Water Quality Standards.

Biosolids are the solid, semisolid, or liquid residues generated during the treatment of sanitary sewage or domestic sewage in a treatment works. This includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes and a derivative of the removed scum or solids.

Bulk biosolids means biosolids that are not sold or given away in a bag or other container for application to a lawn or home garden.

Certificate of Coverage (COC) is a document, issued by the Department, which authorizes a discharge under a general permit.

Chronic toxic unit (TU_C) means $100/MATC$ or $100/IC_{25}$, where the maximum acceptable toxicant concentration (MATC) and IC_{25} are expressed as a percent effluent in the test medium.

Class B biosolids refers to material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PSRP) in accordance with the Part 24 Rules. Processes include aerobic digestion, composting, anaerobic digestion, lime stabilization and air drying.

Combined sewer system is a sewer system in which storm water runoff is combined with sanitary wastes.

Daily concentration is the sum of the concentrations of the individual samples of a parameter divided by the number of samples taken during any calendar day. If the parameter concentration in any sample is less than the quantification limit, regard that value as zero when calculating the daily concentration. The daily concentration will be used to determine compliance with any maximum and minimum daily concentration limitations (except for pH and dissolved oxygen). When required by the permit, report the maximum calculated daily concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the Discharge Monitoring Reports (DMRs).

For pH, report the maximum value of any *individual* sample taken during the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs and the minimum value of any *individual* sample taken during the month in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs. For dissolved oxygen, report the minimum concentration of any *individual* sample in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

Daily loading is the total discharge by weight of a parameter discharged during any calendar day. This value is calculated by multiplying the daily concentration by the total daily flow and by the appropriate conversion factor. The daily loading will be used to determine compliance with any maximum daily loading limitations. When required by the permit, report the maximum calculated daily loading for the month in the "MAXIMUM" column under "QUANTITY OR LOADING" on the DMRs.

Daily monitoring frequency refers to a 24-hour day. When required by this permit, an analytical result, reading, value or observation shall be reported for that period if a discharge occurs during that period.

Department means the Michigan Department of Environment, Great Lakes, and Energy.

Detection level means the lowest concentration or amount of the target analyte that can be determined to be different from zero by a single measurement at a stated level of probability.

Discharge means the addition of any waste, waste effluent, wastewater, pollutant, or any combination thereof to any surface water of the state.

EC₅₀ means a statistically or graphically estimated concentration that is expected to cause 1 or more specified effects in 50% of a group of organisms under specified conditions.

Fecal coliform bacteria monthly

FOR WWSLs THAT COLLECT AND STORE WASTEWATER AND ARE AUTHORIZED TO DISCHARGE ONLY IN THE SPRING AND/OR FALL ON AN INTERMITTENT BASIS – Fecal coliform bacteria monthly is the geometric mean of all daily concentrations determined during a discharge event. Days on which no daily concentration is determined shall not be used to determine the calculated monthly value. The calculated monthly value will be used to determine compliance with the maximum monthly fecal coliform bacteria limitations. When required by the permit, report the calculated monthly value in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMR. If the period in which the discharge event occurred was partially in each of two months, the calculated monthly value shall be reported on the DMR of the month in which the last day of discharge occurred.

FOR ALL OTHER DISCHARGES – Fecal coliform bacteria monthly is the geometric mean of all daily concentrations determined during a reporting month. Days on which no daily concentration is determined shall not be used to determine the calculated monthly value. The calculated monthly value will be used to determine compliance with the maximum monthly fecal coliform bacteria limitations. When required by the permit, report the calculated monthly value in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMR.

Fecal coliform bacteria 7-day

FOR WWSLs THAT COLLECT AND STORE WASTEWATER AND ARE AUTHORIZED TO DISCHARGE ONLY IN THE SPRING AND/OR FALL ON AN INTERMITTENT BASIS – Fecal coliform bacteria 7-day is the geometric mean of the daily concentrations determined during any 7 consecutive days of discharge during a discharge event. If the number of daily concentrations determined during the discharge event is less than 7 days, the number of actual daily concentrations determined shall be used for the calculation. Days on which no daily concentration is determined shall not be used to determine the value. The calculated 7-day value will be used to determine compliance with the maximum 7-day fecal coliform bacteria limitations. When required by the permit, report the maximum calculated 7-day geometric mean value for the month in the “MAXIMUM” column under “QUALITY OR CONCENTRATION” on the DMRs. If the 7-day period was partially in each of two months, the value shall be reported on the DMR of the month in which the last day of discharge occurred.

FOR ALL OTHER DISCHARGES – Fecal coliform bacteria 7-day is the geometric mean of the daily concentrations determined during any 7 consecutive days in a reporting month. If the number of daily concentrations determined is less than 7, the actual number of daily concentrations determined shall be used for the calculation. Days on which no daily concentration is determined shall not be used to determine the value. The calculated 7-day value will be used to determine compliance with the maximum 7-day fecal coliform bacteria limitations. When required by the permit, report the maximum calculated 7-day geometric mean for the month in the “MAXIMUM” column under “QUALITY OR CONCENTRATION” on the DMRs. The first calculation shall be made on day 7 of the reporting month, and the last calculation shall be made on the last day of the reporting month.

Flow-proportioned sample is a composite sample with the sample volume proportional to the effluent flow.

General permit means a National Pollutant Discharge Elimination System permit issued authorizing a category of similar discharges.

Geometric mean is the average of the logarithmic values of a base 10 data set, converted back to a base 10 number.

Grab sample is a single sample taken at neither a set time nor flow.

IC₂₅ means the toxicant concentration that would cause a 25% reduction in a nonquantal biological measurement for the test population.

Illicit connection means a physical connection to a municipal separate storm sewer system that primarily conveys non-storm water discharges other than uncontaminated groundwater into the storm sewer; or a physical connection not authorized or permitted by the local authority, where a local authority requires authorization or a permit for physical connections.

Illicit discharge means any discharge to, or seepage into, a municipal separate storm sewer system that is not composed entirely of storm water or uncontaminated groundwater. Illicit discharges include non-storm water discharges through pipes or other physical connections; dumping of motor vehicle fluids, household hazardous wastes, domestic animal wastes, or litter; collection and intentional dumping of grass clippings or leaf litter; or unauthorized discharges of sewage, industrial waste, restaurant wastes, or any other non-storm water waste directly into a separate storm sewer.

Individual permit means a site-specific NPDES permit.

Inlet means a catch basin, roof drain, conduit, drain tile, retention pond riser pipe, sump pump, or other point where storm water or wastewater enters into a closed conveyance system prior to discharge off site or into waters of the state.

Interference is a discharge which, alone or in conjunction with a discharge or discharges from other sources, both: 1) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and 2) therefore, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or, of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent state or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including state regulations contained in any state sludge management plan prepared pursuant to Subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act. [This definition does not apply to sample matrix interference].

Land application means spraying or spreading biosolids or a biosolids derivative onto the land surface, injecting below the land surface, or incorporating into the soil so that the biosolids or biosolids derivative can either condition the soil or fertilize crops or vegetation grown in the soil.

LC₅₀ means a statistically or graphically estimated concentration that is expected to be lethal to 50% of a group of organisms under specified conditions.

Maximum acceptable toxicant concentration (MATC) means the concentration obtained by calculating the geometric mean of the lower and upper chronic limits from a chronic test. A lower chronic limit is the highest tested concentration that did not cause the occurrence of a specific adverse effect. An upper chronic limit is the lowest tested concentration which did cause the occurrence of a specific adverse effect and above which all tested concentrations caused such an occurrence.

Maximum extent practicable means implementation of best management practices by a public body to comply with an approved storm water management program as required by a national permit for a municipal separate storm sewer system, in a manner that is environmentally beneficial, technically feasible, and within the public body's legal authority.

MGD means million gallons per day.

Monthly concentration is the sum of the daily concentrations determined during a reporting period divided by the number of daily concentrations determined. The calculated monthly concentration will be used to determine compliance with any maximum monthly concentration limitations. Days with no discharge shall not be used to determine the value. When required by the permit, report the calculated monthly concentration in the "AVERAGE" column under "QUALITY OR CONCENTRATION" on the DMR.

For minimum percent removal requirements, the monthly influent concentration and the monthly effluent concentration shall be determined. The calculated monthly percent removal, which is equal to 100 times the quantity [1 minus the quantity (monthly effluent concentration divided by the monthly influent concentration)], shall be reported in the "MINIMUM" column under "QUALITY OR CONCENTRATION" on the DMRs.

Monthly loading is the sum of the daily loadings of a parameter divided by the number of daily loadings determined during a reporting period. The calculated monthly loading will be used to determine compliance with any maximum monthly loading limitations. Days with no discharge shall not be used to determine the value. When required by the permit, report the calculated monthly loading in the "AVERAGE" column under "QUANTITY OR LOADING" on the DMR.

Monthly monitoring frequency refers to a calendar month. When required by this permit, an analytical result, reading, value or observation shall be reported for that period if a discharge occurs during that period.

Municipal separate storm sewer means a conveyance or system of conveyances designed or used for collecting or conveying storm water which is not a combined sewer and which is not part of a publicly-owned treatment works as defined in the Code of Federal Regulations at 40 CFR 122.2.

Municipal separate storm sewer system (MS4) means all separate storm sewers that are owned or operated by the United States, a state, city, village, township, county, district, association, or other public body created by or pursuant to state law, having jurisdiction over disposal of sewage, industrial wastes, storm water, or other wastes, including special districts under state law, such as a sewer district, flood control district, or drainage district, or similar entity, or a designated or approved management agency under Section 208 of the Federal Act that discharges to the waters of the state. This term includes systems similar to separate storm sewer systems in municipalities, such as systems at military bases, large hospital or prison complexes, and highways and other thoroughfares. The term does not include separate storm sewers in very discrete areas, such as individual buildings.

National Pretreatment Standards are the regulations promulgated by or to be promulgated by the Federal Environmental Protection Agency pursuant to Section 307(b) and (c) of the Federal Act. The standards establish nationwide limits for specific industrial categories for discharge to a POTW.

No observed adverse effect level (NOAEL) means the highest tested dose or concentration of a substance which results in no observed adverse effect in exposed test organisms where higher doses or concentrations result in an adverse effect.

Noncontact cooling water is water used for cooling which does not come into direct contact with any raw material, intermediate product, by-product, waste product or finished product.

Nondomestic user is any discharger to a POTW that discharges wastes other than or in addition to water-carried wastes from toilet, kitchen, laundry, bathing or other facilities used for household purposes.

Outfall is the location at which a point source discharge enters the surface waters of the state.

Part 91 agency means an agency that is designated by a county board of commissioners pursuant to the provisions of section 9105 of Part 91 of the NREPA; an agency that is designated by a city, village, or township in accordance with the provisions of section 9106 of Part 91 of the NREPA; or the Department for soil erosion and sedimentation activities under Part 615, Part 631, or Part 632 pursuant to the provisions of section 9115 of Part 91 of the NREPA.

Part 91 permit means a soil erosion and sedimentation control permit issued by a Part 91 agency pursuant to the provisions of Part 91 of the NREPA.

Partially treated sewage is any sewage, sewage and storm water, or sewage and wastewater, from domestic or industrial sources that is treated to a level less than that required by the permittees' National Pollutant Discharge Elimination System permit, or that is not treated to national secondary treatment standards for wastewater, including discharges to surface waters from retention treatment facilities.

Point of discharge is the location of a point source discharge where storm water is discharged directly into a separate storm sewer system.

Point source discharge means a discharge from any discernible, confined, discrete conveyance, including but not limited to any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, or rolling stock. Changing the surface of land or establishing grading patterns on land will result in a point source discharge where the runoff from the site is ultimately discharged to waters of the state.

Polluting material means any material, in solid or liquid form, identified as a polluting material under the Part 5 Rules (R 324.2001 through R 324.2009 of the Michigan Administrative Code).

POTW is a publicly owned treatment work.

Pretreatment is reducing the amount of pollutants, eliminating pollutants, or altering the nature of pollutant properties to a less harmful state prior to discharge into a public sewer. The reduction or alteration can be by physical, chemical, or biological processes, process changes, or by other means. Dilution is not considered pretreatment unless expressly authorized by an applicable National Pretreatment Standard for a particular industrial category.

Public (as used in the MS4 individual permit) means all persons who potentially could affect the authorized storm water discharges, including, but not limited to, residents, visitors to the area, public employees, businesses, industries, and construction contractors and developers.

Public body means the United States; the state of Michigan; a city, village, township, county, school district, public college or university, or single-purpose governmental agency; or any other body which is created by federal or state statute or law.

Qualified Personnel means an individual who meets qualifications acceptable to the Department and who is authorized by an Industrial Storm Water Certified Operator to collect the storm water sample.

Qualifying storm event means a storm event causing greater than 0.1 inch of rainfall and occurring at least 72 hours after the previous measurable storm event that also caused greater than 0.1 inch of rainfall. Upon request, the Department may approve an alternate definition meeting the condition of a qualifying storm event.

Quantification level means the measurement of the concentration of a contaminant obtained by using a specified laboratory procedure calculated at a specified concentration above the detection level. It is considered the lowest concentration at which a particular contaminant can be quantitatively measured using a specified laboratory procedure for monitoring of the contaminant.

Quarterly monitoring frequency refers to a three month period, defined as January through March, April through June, July through September, and October through December. When required by this permit, an analytical result, reading, value or observation shall be reported for that period if a discharge occurs during that period.

Regional Administrator is the Region 5 Administrator, U.S. EPA, located at R-19J, 77 W. Jackson Blvd., Chicago, Illinois 60604.

Regulated area means the permittee's urbanized area, where urbanized area is defined as a place and its adjacent densely-populated territory that together have a minimum population of 50,000 people as defined by the United States Bureau of the Census and as determined by the latest available decennial census.

Secondary containment structure means a unit, other than the primary container, in which significant materials are packaged or held, which is required by State or Federal law to prevent the escape of significant materials by gravity into sewers, drains, or otherwise directly or indirectly into any sewer system or to the surface or ground waters of this state.

Separate storm sewer system means a system of drainage, including, but not limited to, roads, catch basins, curbs, gutters, parking lots, ditches, conduits, pumping devices, or man-made channels, which is not a combined sewer where storm water mixes with sanitary wastes, and is not part of a POTW.

Significant industrial user is a nondomestic user that: 1) is subject to Categorical Pretreatment Standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N; or 2) discharges an average of 25,000 gallons per day or more of process wastewater to a POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater); contributes a process waste stream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or is designated as such by the permittees as defined in 40 CFR 403.12(a) on the basis that the industrial user has a reasonable potential for adversely affecting the POTW's treatment plant operation or violating any pretreatment standard or requirement (in accordance with 40 CFR 403.8(f)(6)).

Significant materials Significant Materials means any material which could degrade or impair water quality, including but not limited to: raw materials; fuels; solvents, detergents, and plastic pellets; finished materials such as metallic products; hazardous substances designated under Section 101(14) of Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA) (see 40 CFR 372.65); any chemical the facility is required to report pursuant to Section 313 of Emergency Planning and Community Right-to-Know Act (EPCRA); polluting materials as identified under the Part 5 Rules (R 324.2001 through R 324.2009 of the Michigan Administrative Code); Hazardous Wastes as defined in Part 111 of the NREPA; fertilizers; pesticides; and waste products such as ashes, slag, and sludge that have the potential to be released with storm water discharges.

Significant spills and significant leaks means any release of a polluting material reportable under the Part 5 Rules (R 324.2001 through R 324.2009 of the Michigan Administrative Code).

Special-use area means secondary containment structures required by state or federal law; lands on Michigan's List of Sites of Environmental Contamination pursuant to Part 201, Environmental Remediation, of the NREPA; and/or areas with other activities that may contribute pollutants to the storm water for which the Department determines monitoring is needed.

Stoichiometric means the quantity of a reagent calculated to be necessary and sufficient for a given chemical reaction.

Storm water means storm water runoff, snow melt runoff, surface runoff and drainage, and non-storm water included under the conditions of this permit.

Storm water discharge point is the location where the point source discharge of storm water is directed to surface waters of the state or to a separate storm sewer. It includes the location of all point source discharges where storm water exits the facility, including *outfalls* which discharge directly to surface waters of the state, and *points of discharge* which discharge directly into separate storm sewer systems.

SWPPP means the Storm Water Pollution Prevention Plan prepared in accordance with this permit.

Tier I value means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier I toxicity database.

Tier II value means a value for aquatic life, human health or wildlife calculated under R 323.1057 of the Water Quality Standards using a tier II toxicity database.

Total maximum daily loads (TMDLs) are required by the Federal Act for waterbodies that do not meet water quality standards. TMDLs represent the maximum daily load of a pollutant that a waterbody can assimilate and meet water quality standards, and an allocation of that load among point sources, nonpoint sources, and a margin of safety.

Toxicity reduction evaluation (TRE) means a site-specific study conducted in a stepwise process designed to identify the causative agents of effluent toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in effluent toxicity.

Water Quality Standards means the Part 4 Water Quality Standards promulgated pursuant to Part 31 of the NREPA, being R 323.1041 through R 323.1117 of the Michigan Administrative Code.

Weekly monitoring frequency refers to a calendar week which begins on Sunday and ends on Saturday. When required by this permit, an analytical result, reading, value or observation shall be reported for that period if a discharge occurs during that period.

Wet Weather Flow is the wastewater flow (domestic, industrial, commercial and institutional) including infiltration and inflow that occurs as the result of a precipitation or snowmelt event.

Wet Weather Event, for the interim period, is defined as those days on which an average 0.10 inches or more of precipitation was recorded by six strategically located rainfall gauges (as defined in Part I.9.c.(10) of the Operational Plan) in the WRRF's service area, plus two days immediately following days of 0.10 inch to 1.00 inch days of precipitation or three days following days of 1.00 inch or more precipitation. Rainfall days are further limited to those days in which the air temperature exceeds 32° F (0° C) for at least an eight hour period. The permittee may demonstrate that certain events such as snowmelt, and other unforeseen events will be considered rainfall days.

The above definition of wet weather event is not adequate on a long term basis, or for the purposes of planning, designing, or implementing the combined sewer overflow improvements required in this permit. For purposes of planning and designing future CSO improvements, the permittee shall consider the effect of dewatering tributary storage basins on overall system recovery, both at the WRRF and CSO overflow points in the collection system.

For this permit while the Regional Operational Plan is being revised, if up to 930 MGD (including recycle) is being processed with secondary treatment at the WRRF and no primary flow is being discharged, then tributary combined or sanitary storage basins in the GLWA system may be dewatered. Such dewatering will not be considered a violation of this permit, even if contrary to the above Wet Weather Event definition. Once a revised Regional Operation Plan is developed, it shall be implemented once reviewed and approved by the Department.

Upon approval of the Department, an alternate "wet weather event" definition may be used.

WWSL is a wastewater stabilization lagoon.

WWSL discharge event is a discrete occurrence during which effluent is discharged to the surface water up to 10 days of a consecutive 14 day period.

3-portion composite sample is a sample consisting of three equal-volume grab samples collected at equal intervals over an 8-hour period.

7-day concentration

FOR WWSLs THAT COLLECT AND STORE WASTEWATER AND ARE AUTHORIZED TO DISCHARGE ONLY IN THE SPRING AND/OR FALL ON AN INTERMITTENT BASIS – The 7-day concentration is the sum of the daily concentrations determined during any 7 consecutive days of discharge during a WWSL discharge event divided by the number of daily concentrations determined. If the number of daily concentrations determined during the WWSL discharge event is less than 7 days, the number of actual daily concentrations determined shall be used for the calculation. The calculated 7-day concentration will be used to determine compliance with any maximum 7-day concentration limitations. When required by the permit, report the maximum calculated 7-day concentration for the WWSL discharge event in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMR. If the WWSL discharge event was partially in each of two months, the value shall be reported on the DMR of the month in which the last day of discharge occurred.

FOR ALL OTHER DISCHARGES – The 7-day concentration is the sum of the daily concentrations determined during any 7 consecutive days in a reporting month divided by the number of daily concentrations determined. If the number of daily concentrations determined is less than 7, the actual number of daily concentrations determined shall be used for the calculation. The calculated 7-day concentration will be used to determine compliance with any maximum 7-day concentration limitations in the reporting month. When required by the permit, report the maximum calculated 7-day concentration for the month in the "MAXIMUM" column under "QUALITY OR CONCENTRATION" on the DMR. The first 7-day calculation shall be made on day 7 of the reporting month, and the last calculation shall be made on the last day of the reporting month.

7-day loading

FOR WWSLs THAT COLLECT AND STORE WASTEWATER AND ARE AUTHORIZED TO DISCHARGE ONLY IN THE SPRING AND/OR FALL ON AN INTERMITTENT BASIS – The 7-day loading is the sum of the daily loadings determined during any 7 consecutive days of discharge during a WWSL discharge event divided by the number of daily loadings determined. If the number of daily loadings determined during the WWSL discharge event is less than 7 days, the number of actual daily loadings determined shall be used for the calculation. The calculated 7-day loading will be used to determine compliance with any maximum 7-day loading limitations. When required by the permit, report the maximum calculated 7-day loading for the WWSL discharge event in the “MAXIMUM” column under “QUANTITY OR LOADING” on the DMR. If the WWSL discharge event was partially in each of two months, the value shall be reported on the DMR of the month in which the last day of discharge occurred

FOR ALL OTHER DISCHARGES – The 7-day loading is the sum of the daily loadings determined during any 7 consecutive days in a reporting month divided by the number of daily loadings determined. If the number of daily loadings determined is less than 7, the actual number of daily loadings determined shall be used for the calculation. The calculated 7-day loading will be used to determine compliance with any maximum 7-day loading limitations in the reporting month. When required by the permit, report the maximum calculated 7-day loading for the month in the “MAXIMUM” column under “QUANTITY OR LOADING” on the DMR. The first 7-day calculation shall be made on day 7 of the reporting month, and the last calculation shall be made on the last day of the reporting month.

24-hour composite sample is a flow-proportioned composite sample consisting of hourly or more frequent portions that are taken over a 24-hour period. In accordance with the Department Approved Wet Weather Operational Plan (See Part I.A.11.), alternate requirements for 24-hour composite sampling may be utilized to satisfy the monitoring requirements of this permit.

PART II

Section B. Monitoring Procedures

1. Representative Samples

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge.

2. Test Procedures

Test procedures for the analysis of pollutants shall conform to regulations promulgated pursuant to Section 304(h) of the Federal Act (40 CFR Part 136 – Guidelines Establishing Test Procedures for the Analysis of Pollutants), unless specified otherwise in this permit. **Test procedures used shall be sufficiently sensitive to determine compliance with applicable effluent limitations.** Requests to use test procedures not promulgated under 40 CFR Part 136 for pollutant monitoring required by this permit shall be made in accordance with the Alternate Test Procedures regulations specified in 40 CFR 136.4. These requests shall be submitted to the Section Manager of the Permits Section, Water Resources Division, Michigan Department of Environment, Great Lakes, and Energy, P.O. Box 30458, Lansing, Michigan, 48909-7958. The permittees may use such procedures upon approval.

The permittees shall periodically calibrate and perform maintenance procedures on all analytical instrumentation at intervals to ensure accuracy of measurements. The calibration and maintenance shall be performed as part of the permittees' laboratory Quality Control/Quality Assurance program.

3. Instrumentation

The permittees shall periodically calibrate and perform maintenance procedures on all monitoring instrumentation at intervals to ensure accuracy of measurements.

4. Recording Results

For each measurement or sample taken pursuant to the requirements of this permit, the permittees shall record the following information: 1) the exact place, date, and time of measurement or sampling; 2) the person(s) who performed the measurement or sample collection; 3) the dates the analyses were performed; 4) the person(s) who performed the analyses; 5) the analytical techniques or methods used; 6) the date of and person responsible for equipment calibration; and 7) the results of all required analyses.

5. Records Retention

All records and information resulting from the monitoring activities required by this permit including all records of analyses performed and calibration and maintenance of instrumentation and recordings from continuous monitoring instrumentation shall be retained for a minimum of three (3) years, or longer if requested by the Regional Administrator or the Department.

PART II

Section C. Reporting Requirements

1. Start-up Notification

If the permittees will not discharge during the first 60 days following the effective date of this permit, the permittees shall notify the Department within 14 days following the effective date of this permit, and then 60 days prior to the commencement of the discharge.

2. Submittal Requirements for Self-Monitoring Data

Part 31 of the NREPA (specifically Section 324.3110(7)); and R 323.2155(2) of Part 21, Wastewater Discharge Permits, promulgated under Part 31 of the NREPA, allow the Department to specify the forms to be utilized for reporting the required self-monitoring data. Unless instructed on the effluent limitations page to conduct "Retained Self-Monitoring," the permittees shall submit self-monitoring data via the Department's MiWaters system.

The permittees shall utilize the information provided on the MiWaters website, located at <https://miwaters.deq.state.mi.us>, to access and submit the electronic forms. Both monthly summary and daily data shall be submitted to the Department no later than the 20th day of the month following each month of the authorized discharge period(s). The permittees may be allowed to submit the electronic forms after this date if the Department has granted an extension to the submittal date.

3. Retained Self-Monitoring Requirements

If instructed on the effluent limits page (or otherwise authorized by the Department in accordance with the provisions of this permit) to conduct retained self-monitoring, the permittees shall maintain a year-to-date log of retained self-monitoring results and, upon request, provide such log for inspection to the staff of the Department. Retained self-monitoring results are public information and shall be promptly provided to the public upon request.

The permittees shall certify, in writing, to the Department, on or before January 10th (April 1st for animal feeding operation facilities) of each year, that: 1) all retained self-monitoring requirements have been complied with and a year-to-date log has been maintained; and 2) the application on which this permit is based still accurately describes the discharge. With this annual certification, the permittees shall submit a summary of the previous year's monitoring data. The summary shall include maximum values for samples to be reported as daily maximums and/or monthly maximums and minimum values for any daily minimum samples.

Retained self-monitoring may be denied to permittees by notification in writing from the Department. In such cases, the permittees shall submit self-monitoring data in accordance with Part II.C.2., above. Such a denial may be rescinded by the Department upon written notification to the permittees. Reissuance or modification of this permit or reissuance or modification of an individual permittees' authorization to discharge shall not affect previous approval or denial for retained self-monitoring unless the Department provides notification in writing to the permittees.

4. Additional Monitoring by Permittees

If the permittees monitor any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the Discharge Monitoring Report. Such increased frequency shall also be indicated.

Monitoring required pursuant to Part 41 of the NREPA or Rule 35 of the Mobile Home Park Commission Act (Act 96 of the Public Acts of 1987) for assurance of proper facility operation shall be submitted as required by the Department.

5. Compliance Dates Notification

Within 14 days of every compliance date specified in this permit, the permittees shall submit a *written* notification to the Department indicating whether or not the particular requirement was accomplished. If the requirement was not accomplished, the notification shall include an explanation of the failure to accomplish the requirement, actions taken or planned by the permittees to correct the situation, and an estimate of when the requirement will be accomplished. If a written report is required to be submitted by a specified date and the permittees accomplish this, a separate written notification is not required.

6. Noncompliance Notification

Compliance with all applicable requirements set forth in the Federal Act, Parts 31 and 41 of the NREPA, and related regulations and rules is required. All instances of noncompliance shall be reported as follows:

- a. **24-Hour Reporting**
Any noncompliance which may endanger health or the environment (including maximum and/or minimum daily concentration discharge limitation exceedances) shall be reported, verbally, within 24 hours from the time the permittees becomes aware of the noncompliance. A written submission shall also be provided within five (5) days.
- b. **Other Reporting**
The permittees shall report, in writing, all other instances of noncompliance not described in a. above at the time monitoring reports are submitted; or, in the case of retained self-monitoring, within five (5) days from the time the permittees become aware of the noncompliance.

Written reporting shall include: 1) a description of the discharge and cause of noncompliance; and 2) the period of noncompliance, including exact dates and times, or, if not yet corrected, the anticipated time the noncompliance is expected to continue, and the steps taken to reduce, eliminate and prevent recurrence of the noncomplying discharge.

7. Spill Notification

The permittees shall immediately report any release of any polluting material which occurs to the surface waters or groundwaters of the state, unless the permittees have determined that the release is not in excess of the threshold reporting quantities specified in the Part 5 Rules (R 324.2001 through R 324.2009 of the Michigan Administrative Code), by calling the Department at the number indicated on the second page of this permit (or, if this is a general permit, on the COC); or, if the notice is provided after regular working hours, call the Department's 24-hour Pollution Emergency Alerting System telephone number, 1-800-292-4706 (calls from **out-of-state** dial 1-517-373-7660).

Within ten (10) days of the release, the permittees shall submit to the Department a full written explanation as to the cause of the release, the discovery of the release, response (clean-up and/or recovery) measures taken, and preventive measures taken or a schedule for completion of measures to be taken to prevent reoccurrence of similar releases.

8. Upset Noncompliance Notification

If a process "upset" (defined as an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittees) has occurred, the permittees who wishes to establish the affirmative defense of upset, shall notify the Department by telephone within 24 hours of becoming aware of such conditions; and within five (5) days, provide in writing, the following information:

- a. that an upset occurred and that the permittees can identify the specific cause(s) of the upset;
- b. that the permitted wastewater treatment facility was, at the time, being properly operated and maintained (note that an upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation); and
- c. that the permittees has specified and taken action on all responsible steps to minimize or correct any adverse impact in the environment resulting from noncompliance with this permit.

No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

In any enforcement proceedings, the permittees, seeking to establish the occurrence of an upset, has the burden of proof.

9. Bypass Prohibition and Notification

- a. Bypass Prohibition
Bypass is prohibited, and the Department may take an enforcement action, unless:
 - 1) bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - 2) there were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass; and
 - 3) the permittees submitted notices as required under 9.b. or 9.c. below.
- b. Notice of Anticipated Bypass
If the permittees know in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least ten (10) days before the date of the bypass, and provide information about the anticipated bypass as required by the Department. The Department may approve an anticipated bypass, after considering its adverse effects, if it will meet the three (3) conditions listed in 9.a. above.
- c. Notice of Unanticipated Bypass
The permittees shall submit notice to the Department of an unanticipated bypass by calling the Department at the number indicated on the second page of this permit (if the notice is provided after regular working hours, use the following number: 1-800-292-4706) as soon as possible, but no later than 24 hours from the time the permittees becomes aware of the circumstances.

- d. **Written Report of Bypass**
A written submission shall be provided within five (5) working days of commencing any bypass to the Department, and at additional times as directed by the Department. The written submission shall contain a description of the bypass and its cause; the period of bypass, including exact dates and times, and if the bypass has not been corrected, the anticipated time it is expected to continue; steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass; and other information as required by the Department.
- e. **Bypass Not Exceeding Limitations**
The permittees may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to ensure efficient operation. These bypasses are not subject to the provisions of 9.a., 9.b., 9.c., and 9.d., above. This provision does not relieve the permittees of any notification responsibilities under Part II.C.11. of this permit.
- f. **Definitions**
- 1) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
 - 2) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

10. Bioaccumulative Chemicals of Concern (BCC)

Consistent with the requirements of R 323.1098 and R 323.1215 of the Michigan Administrative Code, the permittees are prohibited from undertaking any action that would result in a lowering of water quality from an increased loading of a BCC unless an increased use request and antidegradation demonstration have been submitted and approved by the Department.

11. Notification of Changes in Discharge

The permittees shall notify the Department, in writing, as soon as possible but no later than 10 days of knowing, or having reason to believe, that any activity or change has occurred or will occur which would result in the discharge of: 1) detectable levels of chemicals on the current Michigan Critical Materials Register, priority pollutants or hazardous substances set forth in 40 CFR 122.21, Appendix D, or the Pollutants of Initial Focus in the Great Lakes Water Quality Initiative specified in 40 CFR 132.6, Table 6, which were not acknowledged in the application or listed in the application at less than detectable levels; 2) detectable levels of any other chemical not listed in the application or listed at less than detection, for which the application specifically requested information; or 3) any chemical at levels greater than five times the average level reported in the complete application (see the first page of this permit, for the date(s) the complete application was submitted). Any other monitoring results obtained as a requirement of this permit shall be reported in accordance with the compliance schedules.

12. Changes in Facility Operations

Any anticipated action or activity, including but not limited to facility expansion, production increases, or process modification, which will result in new or increased loadings of pollutants to the receiving waters must be reported to the Department by a) submission of an increased use request (application) and all information required under R 323.1098 (Antidegradation) of the Water Quality Standards or b) by notice if the following conditions are met: 1) the action or activity will not result in a change in the types of wastewater discharged or result in a greater quantity of wastewater than currently authorized by this permit; 2) the action or activity will not result in violations of the effluent limitations specified in this permit; 3) the action or activity is not prohibited by the requirements of Part II.C.10.; and 4) the action or activity will not require notification pursuant to Part II.C.11. Following such notice, the permit or, if applicable, the facility's COC may be modified according to applicable laws and rules to specify and limit any pollutant not previously limited.

13. Transfer of Ownership or Control

In the event of any change in control or ownership of facilities from which the authorized discharge emanates, the permittees shall submit to the Department 30 days prior to the actual transfer of ownership or control a written agreement between the current permittees and the new permittees containing: 1) the legal name and address of the new owner; 2) a specific date for the effective transfer of permit responsibility, coverage and liability; and 3) a certification of the continuity of or any changes in operations, wastewater discharge, or wastewater treatment.

If the new permittees are proposing changes in operations, wastewater discharge, or wastewater treatment, the Department may propose modification of this permit in accordance with applicable laws and rules.

14. Operations and Maintenance Manual

For wastewater treatment facilities that serve the public (and are thus subject to Part 41 of the NREPA), Section 4104 of Part 41 and associated Rule 2957 of the Michigan Administrative Code allow the Department to require an Operations and Maintenance (O&M) Manual from the facility. An up-to-date copy of the O&M Manual shall be kept at the facility and shall be provided to the Department upon request. The Department may review the O&M Manual in whole or in part at its discretion and require modifications to it if portions are determined to be inadequate.

At a minimum, the O&M Manual shall include the following information: permit standards; descriptions and operation information for all equipment; staffing information; laboratory requirements; record keeping requirements; a maintenance plan for equipment; an emergency operating plan; safety program information; and copies of all pertinent forms, as-built plans, and manufacturer's manuals.

Certification of the existence and accuracy of the O&M Manual shall be submitted to the Department at least sixty days prior to start-up of a new wastewater treatment facility. Recertification shall be submitted sixty days prior to start-up of any substantial improvements or modifications made to an existing wastewater treatment facility.

15. Signatory Requirements

All applications, reports, or information submitted to the Department in accordance with the conditions of this permit and that require a signature shall be signed and certified as described in the Federal Act and the NREPA.

The Federal Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

The NREPA (Section 3115(2)) provides that a person who at the time of the violation knew or should have known that he or she discharged a substance contrary to this part, or contrary to a permit, COC, or order issued or rule promulgated under this part, or who intentionally makes a false statement, representation, or certification in an application for or form pertaining to a permit or COC or in a notice or report required by the terms and conditions of an issued permit or COC, or who intentionally renders inaccurate a monitoring device or record required to be maintained by the Department, is guilty of a felony and shall be fined not less than \$2,500.00 or more than \$25,000.00 for each violation. The court may impose an additional fine of not more than \$25,000.00 for each day during which the unlawful discharge occurred. If the conviction is for a violation committed after a first conviction of the person under this subsection, the court shall impose a fine of not less than \$25,000.00 per day and not more than \$50,000.00 per day of violation. Upon conviction, in addition to a fine, the court in its discretion may sentence the defendant to imprisonment for not more than 2 years or impose probation upon a person for a violation of this part. With the exception of the issuance of criminal complaints, issuance of warrants, and the holding of an arraignment, the circuit court for the county in which the violation occurred has exclusive jurisdiction. However, the person shall not be subject to the penalties of this subsection if the discharge of the effluent is in conformance with and obedient to a rule, order, permit, or COC of the Department. In addition to a fine, the attorney general may file a civil suit in a court of competent jurisdiction to recover the full value of the injuries done to the natural resources of the state and the costs of surveillance and enforcement by the state resulting from the violation.

16. Electronic Reporting

Upon notice by the Department that electronic reporting tools are available for specific reports or notifications, the permittees shall submit electronically all such reports or notifications as required by this permit, on forms provided by the Department.

PART II

Section D. Management Responsibilities

1. Duty to Comply

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit, more frequently than, or at a level in excess of, that authorized, shall constitute a violation of the permit.

It is the duty of the permittees to comply with all the terms and conditions of this permit. Any noncompliance with the Effluent Limitations, Special Conditions, or terms of this permit constitutes a violation of the NREPA and/or the Federal Act and constitutes grounds for enforcement action; for permit or Certificate of Coverage (COC) termination, revocation and reissuance, or modification; or denial of an application for permit or COC renewal.

It shall not be a defense for permittees in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

2. Operator Certification

The permittees shall have the waste treatment facilities under direct supervision of an operator certified at the appropriate level for the facility certification by the Department, as required by Sections 3110 and 4104 of the NREPA. Permittees authorized to discharge storm water shall have the storm water treatment and/or control measures under direct supervision of a storm water operator certified by the Department, as required by Section 3110 of the NREPA.

3. Facilities Operation

The permittees shall, at all times, properly operate and maintain all treatment or control facilities or systems installed or used by the permittees to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance includes adequate laboratory controls and appropriate quality assurance procedures.

4. Power Failures

In order to maintain compliance with the effluent limitations of this permit and prevent unauthorized discharges, the permittees shall either:

- a. provide an alternative power source sufficient to operate facilities utilized by the permittees to maintain compliance with the effluent limitations and conditions of this permit; or
- b. upon the reduction, loss, or failure of one or more of the primary sources of power to facilities utilized by the permittees to maintain compliance with the effluent limitations and conditions of this permit, the permittees shall halt, reduce or otherwise control production and/or all discharge in order to maintain compliance with the effluent limitations and conditions of this permit.

5. Adverse Impact

The permittees shall take all reasonable steps to minimize or prevent any adverse impact to the surface waters or groundwaters of the state resulting from noncompliance with any effluent limitation specified in this permit including, but not limited to, such accelerated or additional monitoring as necessary to determine the nature and impact of the discharge in noncompliance.

6. Containment Facilities

The permittees shall provide facilities for containment of any accidental losses of polluting materials in accordance with the requirements of the Part 5 Rules (R 324.2001 through R 324.2009 of the Michigan Administrative Code). For a Publicly Owned Treatment Work (POTW), these facilities shall be approved under Part 41 of the NREPA.

7. Waste Treatment Residues

Residuals (i.e. solids, sludges, biosolids, filter backwash, scrubber water, ash, grit, or other pollutants or wastes) removed from or resulting from treatment or control of wastewaters, including those that are generated during treatment or left over after treatment or control has ceased, shall be disposed of in an environmentally compatible manner and according to applicable laws and rules. These laws may include, but are not limited to, the NREPA, Part 31 for protection of water resources, Part 55 for air pollution control, Part 111 for hazardous waste management, Part 115 for solid waste management, Part 121 for liquid industrial wastes, Part 301 for protection of inland lakes and streams, and Part 303 for wetlands protection. Such disposal shall not result in any unlawful pollution of the air, surface waters or groundwaters of the state.

8. Right of Entry

The permittees shall allow the Department, any agent appointed by the Department, or the Regional Administrator, upon the presentation of credentials and, for animal feeding operation facilities, following appropriate biosecurity protocols:

- a. to enter upon the permittee's premises where an effluent source is located or any place in which records are required to be kept under the terms and conditions of this permit; and
- b. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this permit; to inspect process facilities, treatment works, monitoring methods and equipment regulated or required under this permit; and to sample any discharge of pollutants.

9. Availability of Reports

Except for data determined to be confidential under Section 308 of the Federal Act and Rule 2128 (R 323.2128 of the Michigan Administrative Code), all reports prepared in accordance with the terms of this permit, shall be available for public inspection at the offices of the Department and the Regional Administrator. As required by the Federal Act, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the Federal Act and Sections 3112, 3115, 4106 and 4110 of the NREPA.

10. Duty to Provide Information

The permittees shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or the facility's COC, or to determine compliance with this permit. The permittees shall also furnish to the Department, upon request, copies of records required to be kept by this permit.

Where the permittees become aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

PART II**Section E. Activities Not Authorized by This Permit****1. Discharge to the Groundwaters**

This permit does not authorize any discharge to the groundwaters. Such discharge may be authorized by a groundwater discharge permit issued pursuant to the NREPA.

2. POTW Construction

This permit does not authorize or approve the construction or modification of any physical structures or facilities at a POTW. Approval for the construction or modification of any physical structures or facilities at a POTW shall be by permit issued under Part 41 of the NREPA.

3. Civil and Criminal Liability

Except as provided in permit conditions on "Bypass" (Part II.C.9. pursuant to 40 CFR 122.41(m)), nothing in this permit shall be construed to relieve the permittees from civil or criminal penalties for noncompliance, whether or not such noncompliance is due to factors beyond the permittee's control, such as accidents, equipment breakdowns, or labor disputes.

4. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittees from any responsibilities, liabilities, or penalties to which the permittees may be subject under Section 311 of the Federal Act except as are exempted by federal regulations.

5. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittees from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Federal Act.

6. Property Rights

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize violation of any federal, state or local laws or regulations, nor does it obviate the necessity of obtaining such permits, including any other Department of Environment, Great Lakes, and Energy permits, or approvals from other units of government as may be required by law.